



iJRASET

International Journal For Research in
Applied Science and Engineering Technology



INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Volume: 10 Issue: IX Month of publication: September 2022

DOI: <https://doi.org/10.22214/ijraset.2022.46553>

www.ijraset.com

Call:  08813907089

E-mail ID: ijraset@gmail.com

Numerical Modelling and Design Experiment of a Model Gas Turbine Petro with Combination of Natural Gas, Hydrogen

Nnadikwe Johnson¹, Onyewudiala Ibeawuchi Julius², Wopara Onuoha Fidelis³, Samuel H. Kwelle⁴, Ewelike Asterius Dozie⁵

¹H.O.D in Department of Petroleum and Gas Engineering, Imo State University, Nigeria

²Department of Mechanical Engineering, Imo State University, Nigeria

³Department of Petroleum Engineering, Rivers State University, Nigeria

⁴First Independent Power Limited

⁵H.O.D Department of Agriculture and Environmental Engineering, Imo State University, Nigeria

Abstract: In this study, we are constructing an analytical model to evaluate the energy performance of a Micro Gas Turbine (MGT) utilizing H₂ NG mixes as fuel. During the experimental campaign, the model findings were verified in the real working conditions of the Micro Gas Turbine. It was during the spring and summer of this year that a model validation experiment was carried out. Fueled by H₂ NG, MGT performance has been shown to increase from zero to 10 percent hydrogen content, with a 2 percent volume step. Fuel usage has been considerably decreased, according to the data. Heat recovery and electrical reliability increase marginally even if environmental conditions have an influence on the system. A MATLAB-Simulink numerical model was built to depict the MGT's operation. As a consequence, the relative standard errors of the major output parameters have been determined.

Keywords: Numerical, Gas Turbine, Modelling, Natural Gas, Hydrogen

I. INTRODUCTION

Global warming is a serious concern, and solving it is amongst the most challenging. Decarbonizing the energy system and substituting fossil sources of renewable energy may reduce GHG emissions. It is critical that the energy utilized is safe, reliable, affordable, and long-term. Wind and solar energy are examples of renewable energy sources. Devout believers in the future of these technologies, their execution is fraught with difficulties. A Power to Gas technique uses hydrogen as an energy transporter to store power. In a pressure tank or a metal hydride tank, water electrolysis produces hydrogen.

One of the most common uses for hydrogen is as a fuel for vehicles. Constrisciani et al. defined "hydro methane" as a combination of methane and hydrogen containing 5-30% hydrogen. Hydrogen burns quicker than methane. In gas turbine applications, encouraging increased combustion of hydrocarbon fuels with hydrogen gas is now a good concept. In a combustion chamber, Rajpara et al. discovered that adding hydrogen improves flame temperature, lowers flame dimensions, and so reduces CO emissions. Also investigated was a novel integrated CHP system that incorporated solar energy, a biogas-steam reformer with methanol, and hydrogen production. On the other hand, Ouchikh et al investigated the effects of hydrogen enrichment in natural gas on dual-fuel diesel engines. Cappelletti et al. numerically redesigned a 100 kW MGT combustion chamber for 100% hydrogen, proving that although hydrogen generates more NO_x than CH₄, it can function lean. To test the application's pros and cons, De Santoli et al. used H₂NG mixes in established technologies like internal combustion engines. Based on an experimental campaign, Lo Basso et al. reported on the impact of adding up to 15% H₂ to the fuel mix on electrical and heat recovery efficiency, as well as pollution emissions of a condensing microCHP. Over a year, De Santoli et al. studied the energy and environmental characteristics of a commercial micro gas turbine using hydrogen-enriched natural gas blends. Environmental and economic advantages are claimed for CHP technology. Several research efforts are presently ongoing to develop eco-friendly fuels. A recent research found that burning H₂NG emits the least CO and CO₂. Because hydrogen-enhanced blends burn quicker and have a greater H/C ratio, they may minimize carbon emissions. This study's purpose is to model and examine a commercial Micro Gas Turbine that works on hydrogen and natural gas. This report summarizes key results.

II. DESCRIPTION AND USE OF TEST RIG

This study's objective is to build a compact gas turbine that works on hydrogen and natural gas. The experimental effort DIAEE of Sapienza University in Rome supplied the modeling data. MGT is rated at 30 kWel and 63 KKWth by Capstone Corporation. A series of research that gradually increased the fuel's hydrogen content. Laboratory electrolyte is made using an alkaline electrolyser. MGTs are Brayton cycle-based micro power plants (less than 500 kWel). High-performance gas turbines employ the recovery cycle and feature turbo-radial machinery. This research used the Capstone C30 microgas turbine. Table 1 lists the machine's technical specs.

Table 1. datasheet of Capstone C30

| Parameters | Values |
|---|------------------------------|
| Engine type | Natural gas Micro Turbine |
| Rotational speed | 96,000 rpm |
| Compression ratio | 4:1 |
| Gross Active power | 30 kW |
| Width | 0.76 m |
| Depth | 1.5 m |
| Height | 1.8 m |
| Weight | Grid Connect - 405 kg |
| Net Active Power | 28 kW |
| Voltage | 400 -480 V, AC, PPPN |
| Frequency | 50-60 Hz (Grid Connected) |
| CHP electric efficiency (based on LHV) | 0.26 |
| CHP heat recovery efficiency (based on LHV) | 0.58 |
| Max. thermal output power | 60 kW |
| Hot water flow | 2.9 m ³ /h |
| Exhaust Temperature | 275°C (530°F) |
| Exhaust Gas Flow | 0.31 kg/s |
| Max. operating pressure | 6 bar |
| Average fuel consumption | 11 Nm ³ /h |
| Fuel | Natural gas, Liquid Fuels |

MGTs have a compressor, combustor, turbines, heat reboiler, and generator. They may be powered by natural gas, biogas, and biodiesel. In the commercial Capstone C30 package, process air is compressed by a radial compressor (from stage 1 to state 2) and pre-heated by an annular regenerator utilizing hot turbine exhaust gas (from state 2 to state 2'). (see Figure 1). Micro gas turbines may dramatically boost electrical efficiency at low pressure ratios. In the combustion chamber, the process air is mixed with the fuel (state 3). The expander (4) depressurizes combustion by-products, which are subsequently cooled by the heat regenerator (4 to 4') and transferred via the liquid to gas heat exchanger (5 to 6) to create hot water for the HVAC system. Some MGT energy efficiency features have been measured directly using sensors and probes, while others, especially those linked to intermediate states, have been reverse-engineered. Onboard PLC records power output, rotation speed, input temperature T1, and combustion temperature T3 (Programmable Logic Controller). The gas analyzer temperature probe measured T6 and the thermal counter recorded hot water temperature and flow rate.




Fig. 1. Process layout of Capstone C30.

III. MATLAB-SIMULINK Model

In the simulation model, MATLAB-Simulink was used to implement the compressor, recuperator, combustor, and turbine. To begin, the miniature gas turbine's components were modeled and the equations regulating their functioning were put into action. In the second step, the process system was examined and characterized. Using the model, we can see how the MGT responds to H2NG mixes. Experimentation and calculated outcomes are then compared.

A. Air Compressor

As a centrifugal compressor is attached to the turbo-shaft, alternator's it is referred to as the compressor block. inputs are the intake temperature (TT_1), polytropic efficiency (pt), the air constant (RR), inlet pressure (pp1), the notional compression ratio (cc), and air specific heat (CCpp), which is derived using the equation:

$$T_2 = \beta_c T_1 \frac{k-1}{\eta_{pt}^{k+1}} = \beta_c T_1 \frac{R}{\eta_{pt}^{k+1} C_p} \quad (1)$$

$$p_2 = \beta_c p_1 \quad (2)$$

B. Recuperator

Compressed air flow is warmed in the recuperator, a counter-flow heat exchanger in which exhaust expanded gases are recirculated back to pre-heat compressed air entering the turbine. The subsystem outputs the temperature of the air before it enters the combustion chamber (TT_2'). the approach temperature, represented as ($TT_4 - TT_2'$), which is set to 50°C under nominal circumstances and assessed iteratively on the exchanger exhaust gas temperature, as stated on the technical data sheet for each power output air temperature, and the exhaust flow rate are the system's inputs. The efficiency of a heat exchanger may be calculated if the fluctuation of the approach temperature with the load (that is, with temperatures and flow rates) is known.

The following equation may be used to compute TT_2' :

$$\left(\frac{1+\alpha}{\alpha}\right) C_{p, \text{exhaust}, 4-5} (T_4 - T_5) = C_{p, \text{air}, 2-2'} (T_2' - T_2) \quad (3)$$

C. Combustor

According to an energy density modeling of the combustor, the atmosphere proportion and fuel energy may be determined using the following equation:

$$(1 + \alpha) C_{pp} eeeeehaaaaaa, 2'-3 (TT_3 - TT_2') = LLLLLL \eta ccccccc \quad (4)$$

Where $\eta_{ccccccc}$ is the Combustion efficiency and is calculated by multiplying a particular quantity of fuel by its lower heating value (LHV), which is defined as the amount of heat generated by combusting at 25°C and restoring the temperature of combustion products to 150°C , with water in the reaction products not recovered. Depending on the kind of gasoline used, this amount may range from a few percent to a few percentage points higher or lower.

Turbine

This equation may be used to compute T4 given the nominal expansion ratio (e), the reference (T3), and the polytropic efficiency (pt) in the turbine block.

$$T_4 = \frac{T_3}{\beta_e \frac{\eta_{pt}^{k-1}}{k}} = \frac{T_3}{\beta_e \frac{\eta_{pt} R}{C_p}} \tag{5}$$

Where $\beta_e = \eta_{pp} \beta$, with η_{pp} pneumatic efficiency, which is a measure of total pressure, is expressed as a percentage.

D. Heat Transfer of Water Gas

The MGT might employ a water-gas heat exchanger to finish the heat rehabilitation process. The energy balance models this element.

$$T_{w6} = T_{w5} - \frac{Q_{H2}}{C_{p,w} m_w} = T_{w5} - \frac{C_{p,H2} m_{H2} (T_{H2in} - T_{H2out})}{C_{p,w} m_w} \tag{6}$$

The thermal user selects the flow rate of the water, inlet, and outflow temperatures. The energy balance needs the air flowrate, computed from specific useable power:

$$\dot{m}_{air} = \frac{P_{el}}{\left[\frac{(T_3 - T_4) c_{p,3,4} (1 + \alpha)}{\alpha} c_{p,1,2} (T_2 - T_1) \right] \eta_{el}} \tag{7}$$

IV. RESULTS AND DISCUSSION

This research models and analyzes the MGT mathematical model when utilized to power a machine on Hydrogen and Natural Gas Blends.

A. Model Validation

During testing, the hydrogen fraction in the blended fuels was raised by 2%. A moderate load (15 kW) and the maximum supplied electrical energy (22 kW) were tested on the MGT. The model is fed experimentally measured electrical power, and simulated operating principles are compared to experimental ones.

Table 2. Experiment vs. 15 kW simulation

| 15kW | H ₂ % | | | | | |
|-----------------------------|------------------|---------|---------|---------|---------|---------|
| | 0 % | 2 % | 4 % | 6 % | 8 % | 10 % |
| T ₃ Simulated | 1052.36 | 1051.66 | 1050.34 | 1050.09 | 1050.24 | 1049.52 |
| T ₃ Measurements | 1052 | 1051 | 1051 | 1050 | 1050 | 1049 |
| Error % | 0.0339 | 0.0627 | 0.0628 | 0.0083 | 0.0231 | 0.0500 |
| T ₄ Simulated | 868.164 | 868.164 | 868.164 | 868.164 | 868.164 | 868.164 |
| T ₄ Measurements | 865.044 | 865.156 | 864.737 | 864.4 | 864.462 | 864.362 |
| Error % | 0.3594 | 0.3464 | 0.3947 | 0.4336 | 0.4264 | 0.4379 |
| T ₂ Simulated | 449.92 | 449.94 | 449.92 | 449.96 | 449.92 | 449.91 |
| T ₂ Measurements | 450.133 | 449.484 | 449.918 | 450.446 | 450.996 | 450.235 |
| Error % | 0.0925 | 0.0041 | 0.0518 | 0.2435 | 0.0518 | 0.0744 |

Table 3. Experiment vs. 22 kW simulation

| 22 kW | H ₂ % | | | | | |
|-----------------------------|------------------|---------|---------|---------|---------|---------|
| | 0 % | 2 % | 4 % | 6 % | 8 % | 10 % |
| T ₃ Simulated | 1074 | 1074 | 1075 | 1075 | 1075 | 1073 |
| T ₃ Measurements | 1073.62 | 1074.57 | 1074.18 | 1074.69 | 1075.91 | 1073.57 |
| Error % | 0.0539 | 0.0758 | 0.0289 | 0.0849 | 0.0849 | 0.0534 |
| T ₄ Simulated | 868.164 | 846.961 | 868.164 | 868.164 | 868.164 | 868.164 |
| T ₄ Measurements | 865.04 | 846.30 | 846.43 | 846.46 | 846.22 | 846.23 |
| Error % | 0.0574 | 0.0781 | 0.0626 | 0.0582 | 0.0899 | 0.0855 |
| T ₂ Simulated | 488.51 | 488.52 | 488.51 | 488.52 | 488.51 | 488.52 |
| T ₂ Measurements | 487.13 | 489.35 | 488.30 | 488.82 | 489.30 | 488.85 |
| Error % | 0.278 | 0.176 | 0.039 | 0.066 | 0.164 | 0.073 |

Both simulations (minimum and maximum feasible loads) have a smaller error than the measurement uncertainty, according to results of the study.

B. Modeling of the MGT's H2NG-fuelled functioning

Turbine Inlet Temperature (TIT) values are almost constant since T4 and the expansion ratio are set for each speed and power, with only fluctuations in the heat capacity and the gas steady effecting TIT.




Fig. 2. Change of air to fuel volume ratio at 5,15 and 30 kWel with H2 percent

According to Figures 3 and 4, an improvement in air flow rate may be noted as fuel consumption decreases.




Fig. 3. Change of air to fuel mass flow rate at 5,15 and 30 kWel with H2 percent

The lower heating value of the mixes means that less fuel is needed to produce the same quantity of heat during combustion.




Fig.4. Change of air to fuel Volumetric flow rate at 5,15 and 30 kWel with H2 percent

T2, T3, and T5 are unchanged. The experimental campaign observed the same pattern. When the lower heating value is higher, less fuel is needed to accomplish the same T3-T4 enthalpy difference. Due to combustion energy, the expansion ratio may rise with TIT. Maximum TIT and compress ratio will be reached at a lower RPM, leading in no nominal power. Figure 5 shows that reduced fuel use increases electrical efficiency marginally, offsetting the increased heating value.




Fig.5. Electric utilization at 5,15, and 30 kWel with H2 percent change

Up to 10% H₂ in the combination has no obvious influence on the little gas turbine, although it may boost performance (maximum of nearly 0.01). As thermal power is heavily reliant on waterside parameters and fluctuates little with exhaust flow rate, heat recovery efficiency follows the same pattern. Figure 6 shows heat recovery efficiency at 5, 15, and 30 kW hydrogen concentration.




Fig. 6. Change of heat recovery rate with H2 percent at 5,15 and 30 kWel

V. CONCLUSIONS

The present work models and analyzes a 30 kWel micro gas turbine fed with Hydrogen and Natural Gas mixtures with increasing hydrogen percentages. This research uses MATLAB-Simulink to simulate MGT functioning. Simulations are compared to technical datasheets and experimental campaign data to assure real-world validity. The simulation-reference error is 1.4%. Hydrogen doesn't modify the cycle parameters, yet it reduces fuel usage, showing the model's accuracy. Up to 10% H₂ in the mixture has no influence on the small gas turbine's behavior and significantly boosts its performance.

VI. ACKNOWLEDGEMENT

The authors would like to acknowledge the centre for energy resources and refining technology at Imo State University, Owerri, Nigeria for their technical support, especially providing access to their own software application.

REFERENCES

- [1] European Commission 2018-2020 Climate and energy package.
- [2] Ministry of economic development and the Ministry of the environment and protection of the territory of the sea, National Energy Strategy (SEN) (10 November 2017).
- [3] European Commission 2030 Climate and energy framework available at: https://ec.europa.eu/clima/policies/strategies/2030_en
- [4] L. Wei, P. Geng, A review on natural gas/diesel dual fuel combustion emissions and performance Fuel Process Technol, **142** (2016), pp. 264-278.
- [5] W. Kreuter, H. Hofmann, the important energy transformers in a world of sustainable energy Int J Hydrogen Energy (1998), pp. 661-666.
- [6] Hsin-Yi Shih, Chi-Rong Liu, A computational study on the combustion of hydrogen/methane blended fuels for a micro gas turbine Int J Hydrogen Energy, **39** (2014), pp. 15103-15115.
- [7] HouXin Xiao Sen, Zhang Zhun, QingHu, Experimental and numerical study on engine fueled with different fractions of natural gas-carbon dioxide-hydrogen blends Int J Hydrogen Energy, **44** (11) (26 February 2019), pp. 5599-5606.
- [8] M. Cadorin, M. Pinelli, A. Vaccari, R. Calabria, F. Chiariello, P. Massoli, E. Bi anchi Analysis of a micro gas turbine fed by natural gas and synthesis gas: MGT test bench and combustor CFD analysis J Eng Gas Turbines Power, **134** (7) (2012), Article 071401.
- [9] Marco Antonia Rosa Do Nascimento, Lucilene De Oliveira Rodrigues, Eraldo Cruz dos Santos, Eli Eber Batista Gomes, Micro gas turbine engine, A review www.intechopen.com
- [10] Nicola Constrisciani ENEA, Hydro methane sustainability and market opportunities (April 2009).
- [11] Xu, J., Zhang, X., Zheng, S.-Z., Liu, J.-H., Experimental on combustion stability in an engine fueled with biogas and hydrogen blends, Neiranji Xuebao/Trans CSICE (Chin Soc Intern Combust Engines) **29**(3), pp. 236-240.
- [12] P. Rajpara, R. Shah, J. Banerjee, Effect of hydrogen addition on combustion and emission characteristics of methane fuelled upward swirl can combustor Int J Hydrogen Energy, **43** (2018).
- [13] C. Altantzis, C.E. Frouzakis, A.G. Tomboulides, Detailed numerical simulations of intrinsically unstable two-dimensional planar lean premixed hydrogen/air flames Proc Combust Inst, **1** (2011), pp. 1261-1268.
- [14] S. Ouchikha, M.S. Lounicia, L. Tarabetb, K.LoubarcM. Tazeroutc, Effect of natural gas enrichment with hydrogen on combustion characteristics of a dual fuel diesel engine Int J Hydrogen Energy, **142** (2016), pp. 264-278.
- [15] A. Cappelletti, F. Martelli, E. Bianchi, Trifoni, Numerical redesign of 100kw MGT combustor for 100% H₂ fueling, **45**, Energy Procedia (2014), pp. 14121421.
- [16] Livio De Santoli, Gianluigi Lo Basso, Daniele Bruschi, Preliminary experimental analysis of a CHP hydro methane system, J Energy Power Eng, **7** (2013), pp. 1681-1690.
- [17] Gianluigi Lo Basso, Livio De Santoli, Albo Angelo, Benedetto Nastasi, H₂NG (hydrogen-natural gas mixtures) effects on energy performances of a condensing micro-CHP (combined heat and power) for residential applications: an expeditious assessment of water condensation and experimental analysis Energy, **84** (2015), pp. 397-418
- [18] De Santoli, L., Lo Basso, G., Barati, S., D'Ambra, S., Fasolilli, C, Seasonal energy and environmental characterization of a micro gas turbine fueled with H₂NG blends Energy, (2020), 193, 116678.
- [19] Guglielmo Magri, Costanzo Di Perna Giorgio Serenelli, Analysis of electric and thermal seasonal performances of a residential micro-CHP unit Appl Therm Eng, **36** (April 2012), pp. 193-201 1359-4311.
- [20] M.C. Lee, S. Bin Seo, J.H. Chung, S.M. Kim, Y.J. Joo, D.H. Ahn, Gas turbine combustion performance test of hydrogen and carbon monoxide synthetic gasFuel, **89** (7) (2010), pp. 1485-1491.
- [21] A.R. Khan, M.R. Ravi AnjanRay, Experimental and chemical kinetic studies of the effect of H₂ enrichment on the laminar burning velocity and flame stability of various multicomponent natural gas blends Int J Hydrogen Energy, **44** (2) (8 January 2019), pp. 1192-1212.
- [22] M.S. Lounici, A. Boussadi, K. Loubar, Tazerout, Experimental investigation on NG dual fuel engine improvement by hydrogen enrichment Int J Hydrogen Energy, **36** (2014), p. 21297.
- [23] Aqiang Lin, Qun Zheng, Yuting Jiang, Lin Xiang, Hai Zhang, Sensitivity of air/mist non-equilibrium phase transition cooling to transient characteristics in a compressor of gas turbine Int J Heat Mass, **137** (2019),



10.22214/IJRASET



45.98



IMPACT FACTOR:
7.129



IMPACT FACTOR:
7.429



INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089  (24*7 Support on Whatsapp)