



IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Volume: 5 Issue: XI Month of publication: November 2017 DOI:

www.ijraset.com

Call: 🛇 08813907089 🕴 E-mail ID: ijraset@gmail.com



Energy and Exergy Analysis of a 250 mw Coal Thermal Power Plant at Design Load Conditions

Rakesh Kumar¹, Ajay Berry², Dr. Mahesh Kumar³, Himanshu Manchanda⁴

^{1, 3, 4} Assistant Professor, Mechanical Engineering Department, GJUS&T Hisar (India)-125001. ²Research Scholar, Mechanical Engineering Department, GJUS&T Hisar (India)-125001.

Abstract: In this research work thermodynamic analysis of 250 MW Panipat coal thermal power plants has been carried out by using an energy and exergy analysis method at design load conditions. The exergy analysis of a power plant deals with the analysis of energy on the basis of quantity only however the energy analysis deals with the analysis of energy on the basis of quantity only however the energy analysis deals with the analysis of energy on the basis of quantity as well as quality. The aim of present research work is to conduct an energy and exergy analysis of the major components of a coal thermal power plant like boiler, turbine, and condenser and pump in order to identify the magnitude and location of real energy efficiency. The temperature and pressure of main stream and the condenser pressure are considered as operating parameters. From the study it is observed that the major contribution of energy efficiency is found in pump of 94.56% followed boiler of about 87.11% and condenser of 59.67%. The major exergy efficiency is found in the pump of 91.19% followed by turbine of 52.33% and condenser of 32.40% of the total exergy supplied.

Keywords: Exergy; Energy; Thermal power plant; Energy efficiency; Exergy efficiency.

I. INTRODUCTION

The panipat thermal power station (PTPS) is fully operated by Haryana power generation corporation limited (HPGCL) as it is wholly owned by the state government of Haryana under the Ministry of power (Government of India). Panipat Thermal Power Station was a designated consumer in the state of Haryana, under management of HPGCL. HPGCL was incorporated as company on 17 March 1997 but it came existence on 14 August, 1998 and given the responsibility of operating and maintenance of state own power generating plant and projects. Currently, it had six power station and project situated at panipat, Yamuna Nagar, Hisar and Jhajjar districts [1].



Fig 1.Photographic view of panipat thermal power plant

PTPS is the major coal based and first power station installed in the Haryana by the HPGCL. The plant is located at village Assan which is 12KM away from the city. Total present installed capacity of the power plant 1360MW in six stages as given in the table 1.

rubler. Fear wise instanted capacity of FTTD.			
Stage	Unit	Capacity	Date of installation
Stage-1	Unit-1	110MW	01.11.1979
	Unit-2	110MW	27.03.1980

Table1.Year w	wise installed	capacity of	PTPS
---------------	----------------	-------------	------



International Journal for Research in Applied Science & Engineering Technology (IJRASET) ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor:6.887 Volume 5 Issue XI November 2017- Available at www.ijraset.com

	Unit-3	110MW	01.11.1985
Stage-2			
	Unit-4	110MW	11.01.1987
Stage-3	Unit-5	210MW	28.03.1989
Stage-4	Unit-6	210MW	31.03.2001
Stage-5	Unit-7	250MW	28.092004
Stage-6	Unit-8	250MW	28.01.2005

Transportation of coal is done by wagons. PTPS draws water from right main canal through an intake channel to meet its water requirement. The primary fuel input to the plant is coal which is taken from Jhariya and Raniganj Mines. PTPS disposes bottom ash to the nearest ash pond in slurry form and the dry fly ash to the nearby cement industries and fly ash traders [2]. The project detail of PTPS is given in table 2.

Table 2. Project detail of PTPS		
Sponsor	HPGCL	
Name	Panipat thermal power station(PTPS)	
Location	Assan village, panipat district, Haryana	
Source of financing	Government of India	
Plant capacity	1360MW (4x110+2x210+2x250 MW)	
Total unit	8	
Туре	Coal based thermal power plant	
Coal source	Jhariya and Raniganj mines	
Water source	Canal through	
Plant area	660 acres	
Colony	400 acres	
Ash storage & Raw water	940 acres	

The schematic view of important major components of a thermal power plant, namely, boiler, turbine, condenser and pump are shown in figure 2,3,4 and 5 respectively.



Fig.2 Schematic view of boiler.





Fig. 5. Schematic view of CEP pump

II. THERMAL MODELING AND FORMULAE USED

The energy and exergy analysis of a thermal power plant is studied by using the basic thermodynamics laws. The energy analysis of the thermal power plant has been evaluated by the 1^{st} law and the exergy analysis of thermal power plant studied by the 2^{nd} law of thermodynamic [3]. The energy and exergy analysis of a thermal power plant mainly depend upon the major working components like boiler, turbine, condenser and pump.

A. Energy and exergy analysis boiler

The specifications and the operating parameters of boiler are given in table 3 and 4.



Table 3.Specification of boiler

Туре	Water-tube	
Running Authority	BHEL	
Mode of heat transfer	Natural circulation and sub-critical	

Table 4.Operating parameter of the boiler

Parameter	Unit	Input	Output
Mass flow	TPH	740.88	740.88
Temperature	Celsius	246	537
Pressure	Bar	176.52	150
Enthalpy	kj/kg	1067.6764	3416.57
Entropy	kj/kg-k	2.7263	6.4906

The proximate and ultimate analysis of lignite coal is given in table5 and 6.

Table5.Proximate analysis of coal.		
Coal contents	Units	Value
Fixed carbon	%	21
Volatile matter	%	30
Moisture	%	15
Ash contents	%	34
Calorific value of coal	Kcal/kg	4000
Calorific value of carbon	Kcal/kg	8077.8

Table 6.Ultimate analysis of coal

Coal constituents	Units	Value
Carbon	%	40.58
Hydrogen	%	2.84
Nitrogen	%	0.76
Oxygen	%	7.11
Sulphur	%	0.35
CO_2	%	14.5
Ambient temperature	^{0}C	32
Surface temperature of boiler	^{0}C	352

1) Energy analysis of boiler; The energy analysis of the boiler can be carried out by using the equation 1, 2, 3, 4, 5, 6 and 7 respectively [4-8].

Unburnt carbon loss (L₁)

$$L_1 = \frac{U_C \times CV_C \times 100}{GCV}$$

 $\begin{array}{lll} \mbox{Where:} & U_c\mbox{=}\ Total \ unburnt \ carbon \ in \ ash \\ & CV_c\mbox{=}\ Calorific \ value \ of \ carbon \\ & GCV\mbox{=}\ Gross \ calorific \ value \ of \ carbon \\ \end{array}$

Dry flue gas loss (L₂)

(1)



International Journal for Research in Applied Science & Engineering Technology (IJRASET) ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor:6.887

Volume 5 Issue XI November 2017- Available at www.ijraset.com

(7)

$$L_2 = \frac{M_f \times C_p \times (T_g - T_a) \times 100}{GCV}$$
(2)

Where:M_f= Mass of flue gases

C_p= Specific heat capacity

 T_g = Temperature of flue gas

T_a= Ambient Temperature

Loss due to moisture in fuel (L₃)

$$L_{3} = \frac{M \times \left[584 + C_{p} \left(T_{g} - T_{a}\right)\right]}{GCV} \times 100$$
(3)

Where:M= Total mositure in fuel

Loss due to hydrogen in fuel (L₄)

$$L_4 = \frac{9 \times H \times 584 + C_p (T_g - T_a)}{GCV} \times 100$$
⁽⁴⁾

Where: H= Hydrogen percentage

Loss due to moisture in air (L_5)

$$L_{5} = \frac{AAS \times humidity \ factor \times C_{p \ steam} (T_{g} - T_{a}) \times 100}{GCV}$$
(5)

Where: AAS= Actual mass of air supplied

 $C_{p \text{ steam}} =$ Specific heat capacity steam

Loss due to radiation (L₆)

$$L_{6} = 0.548 \times \left[\left(\frac{T_{s}}{55.55} \right)^{4} - \left(\frac{T_{a}}{55.55} \right)^{4} \right] + 1.957 \times \left(T_{s} - T_{a} \right) \sqrt{\frac{196.85 \times V_{m} + 68.9}{68.9}}$$
(6)

Where: T_s = Temperature of boiler surface

V_m= Wind velocity

Heat loss due to unmeasured loss in boiler (L7)

Total losses $=L_1+L_2+L_3+L_4+L_5+L_6+L_7$

Boiler efficiency = 100-Total losses

2) *Exergy analysis of boiler:* The exergy of boiler in the form of the superheated steam, which is produced with the help of hot flues gasses to convert the water into the steam. The parameters used for exergy efficiency of boiler are given in table 7.

	e i	
Substance	Mass flow rate(TPH)	Temperature (°C)
Fuel (coal)	140	1100
Water	740.833	246
Air supplied	850	140
Steam	740.833	537
Flue Gasses	1100	140

The exergy analysis of boiler can be carried out by using the equation 8, 9, 10, 11, 12, 13 and 14 respectively [9].



Exergy of fuel (\mathcal{E}_{f})

$$\varepsilon_{f} = 34183.16 (C) + 21.95 (N) + 11659.9 (H) + 18242.90 (S) + 13265.9 (O)$$
(8)

Where:

- C= Carbon N= Nitrogen H= hydrogen S= Sulpher
- O=Oxygen

Exergy of feed water (\mathcal{E}_{ω})

$$\varepsilon_{\omega} = \left(C_{p}\right)_{w} \left[\left(T_{w} - T_{o}\right) - T_{o}l_{n} \left(\frac{T_{w}}{T_{o}}\right) \right]$$
(9)

Where

 $(C_p)_w$ = Specific heat of water

T_w= Temperature of feed water

T_w= Referance temperature

Exergy of air supply (\mathcal{E}_a)

$$\varepsilon_{a} = C_{pa} \left[\left(T_{a} - T_{o} \right) - T_{o} l_{n} \left(\frac{T_{a}}{T_{o}} \right) \right]$$
(10)

Where

C_{pa}= Specific heat of air

 T_a = Temperature of air supplied

Exergy of steam formed (\mathcal{E}_s)

$$\varepsilon_s = (h - h_o) - T_o(S - S_o) \tag{11}$$

Where

h= Enthalpy of outlet steam

 h_0 = Enthalpy referance temperature

Exergy of flue gasses(\mathcal{E}_{g})

$$\varepsilon_{g} = C_{pg} \left[\left(T_{g} - T_{o} \right) - T_{o} l_{n} \left(\frac{T_{g}}{T_{o}} \right) \right]$$
(12)

Where

C_{pg}=specific heat of flue gas

The total irreversibility in the steam boiler is given by

 I_b = Total exergy entering the boiler – Total exergy leaving the boiler

$$I_{b} = \left(\varepsilon_{\alpha} + \varepsilon_{\omega} + \varepsilon_{f}\right) - \left(\varepsilon_{s} + \varepsilon_{g}\right)$$
(13)

Exergy efficiency (2nd law efficiency) of boiler

$$\eta_{II} = \frac{\text{total exergy leaving the boiler}}{\text{total exergy entering the boiler}}$$



$$\eta_{II} = \frac{\varepsilon_s + \varepsilon_g}{\varepsilon_\alpha + \varepsilon_\omega + \varepsilon_\omega}$$

(14)

(15)

B. Energy and exergy analysis turbine

The specifications of turbine and operating parameters are given in table 8, 9, 10, 11, 12, 13 and 14 respectively.

Туре	3-Cylinder mixed flow Tanden
Capacity	250MW
Speed	3000 rpm
Overall length	16.975m
Width	10m
Stage	3

1) Energy analysis of turvine

Energy enters in the turbine in the form of the thermal energy of superheated steam coming from the boiler.

Thermal power plant turbine consists of three sections of turbine which are

HP Turbine (High pressure turbine)

IP Turbine (Intermediate pressure turbine)

LP Turbine (low pressure turbine)

a) HP Turbine

Table9. Parameter used for efficiency calculation HP turbine

Parameter	Units	Input	Output
Steam flow	TPH	740.88	655.533
Pressure	Bar	147.1	38.80
Temperature	celsius	537	343.2
Enthalpy	kj/kg	3416.57	3080.8621
Entropy	kj/kg-K	6.4906	6.5770

The energy analysis of turbine can be calculated by using equation 15, 16, 17 and 18 respectively [10]. Isentropic energy efficiency

Isentropic efficiency = $\frac{\text{Actual Work}}{(1 + 1)^{1/2}}$

= $\overline{\text{Iesentropic efficiency}(\text{Ideal work})}$

$$\eta_1 = \frac{h_1 - h_{2a}}{h_1 - h_{2s}}$$

 $h_1 =$ Enthalpy at inlet of HP turbine

 h_{2a} = Enthalpy at outlet of HP turbine

 h_{2s} = Isentropic enthalpy of HP turbine

b) IP Turbine

Parameter	Units	Input	Output
Steam flow	TPH	665.533	586.446
Pressure	kg/cm ²	38.85	6.796
Temperature	Celsius	537	296
Enthalpy	kj/kg	3530.17	3051.92
Entropy	kj/kg-K	7.2116	7.2993

Table 10.Parameter used for efficiency calculation HP turbine



Iesentropi c

(16)

(17)

Isentropic energy efficiency

efficiency =
$$\frac{\text{Actual Work}}{\text{Iesentropi c efficiency (Ideal work)}}$$

 $\eta_1 = \frac{h_1 - h_{2a}}{h_1 - h_{2s}}$

 h_1 =Enthalpy at inlet of IP turbine h_{2a} =Enthalpy at outlet of IP turbine h_{2s} = Isentropic enthalpy of IP turbine

c) LP Turbine

Table 11Parameter used for efficiency calculation HP turbine

Parameter	Units	Input	Output
Steam flow	ТРН	586.446	513.243
Pressure	Bar	6.796	0.1013
Temperature	Celsius	296	46.08
Enthalpy	kj/kg	3051.92	2585.23
Entropy	kj/kg-K	7.2993	8.1466

Isentropic energy efficiency

Iesentropic efficiency = $\frac{\text{Actual Work}}{\text{Iesentropic efficiency (Ideal work)}}$

$$\eta_1 = \frac{h_1 - h_{2a}}{h_1 - h_{2s}}$$

h₁=Enthalpy at inlet of LP turbine

h_{2a}=Enthalpy at outlet of LP turbine

 h_{2s} = Isentropic enthalpy of LP turbine

The energy efficiency of whole turbine is given by the

$$\eta_T = \eta_H \times \eta_I \times \eta_L \tag{18}$$

2) *Exergy analysis of turbine:*Theexergy of the turbine in the form of work done (electric generator), which is being converted from the thermal energy of steam.

Thermal power plant turbine consists of three sections of turbine which are

HP Turbine (High pressure turbine)

IP Turbine (Intermediate pressure turbine)

LP Turbine(low pressure turbine)

a) HP Turbine

Table 12Parameter used for exergy efficiency of HP turbine

Parameter	Units	Input	Output
Steam flow	TPH	740.88	655.533
Pressure	Bar	147.1	38.8049
Temperature	Celsius	537	343.2
Enthalpy	kj/kg	3416.57	3080.8621
Entropy	kj/kg-K	6.4906	6.5770
Exergy	kj/kg	1474.598	1132.206



The exergy analysis of turbine can be calculated by using equation 19, 20, 21, 22, 23, 25, 26, 27 and 28 respectively [11].

Exergatic efficiency =
$$\frac{\text{Exergy Recovered}}{\text{Exergy Supplied}}$$

$$\eta_{II} = 1 - \frac{T_{\circ}S_{gen.}}{\Psi_{1} - \Psi_{2}}$$
(19)
Entropy Generation($S_{gen.}$) = $S_{2} - S_{1}$
(20)

$$\Psi = (h_1 - h_0) - T_0(S_1 - S_0) \tag{21}$$

 Ψ_1 =exergy at inlet

 Ψ_1 =exergy at outlet

b) IP Turbine

Table 13Parameter used for exergy efficiency of IP turbin	ne
---	----

Parameter	Units	Input	Output
Steam flow	TPH	665.533	586.446
Pressure	Bar	38.85	6.796
Temperature	Celsius	537	296
Enthalpy	kj/kg	3530.17	3051.92
Entropy	kj/kg-K	7.2116	7.2993
Exergy	kj/kg	1371.898	867.343

The exergy analysis of turbine can be calculated by using equation 18, 19, 20, 21, 22, 23 and 24 respectively [11-12].

Exergatic efficiency =
$$\frac{\text{Exergy Recovered}}{\text{Exergy Supplied}}$$

 $\eta_{\mu} = 1 - \frac{T_{\circ}S_{gen.}}{T_{\circ}S_{gen.}}$

T (**C**

$$\Psi_1 - \Psi_2 \tag{22}$$

EntropyGeneration $(S_{gen.}) = S_2 - S_1$ (23)

$$\Psi = (h_1 - h_0) - T_0(S_1 - S_0)$$
⁽²⁴⁾

 Ψ_1 =exergy at inlet Ψ_1 =exergy at outlet

c) *LP Turbine*

Table	14 Parameter	used for	everov	efficiency	ofIP	turbine
I able	14.1 al allielei	useu 101	exergy	entrenery	OI LI	turome

Parameter	Units	Input	Output
Steam flow	TPH	586.446	513.243
Pressure	Bar	6.796	0.1013
Temperature	Celsius	296	46.08
Enthalpy	kj/kg	3051.92	2585.23
Entropy	kj/kg-K	7.2993	8.1466
Exergy	kj/kg	867.343	146.458



(26)

(29)

Exergatic efficiency =
$$\frac{\text{Exergy Recovered}}{\text{Exergy Supplied}}$$

$$\eta_{II} = 1 - \frac{T_{\circ}S_{gen.}}{\Psi_1 - \Psi_2}$$
(25)

EntropyGeneration $(S_{gen_1}) = S_2 - S_1$

$$\Psi = (h_1 - h_0) - T_0(S_1 - S_0) \tag{27}$$

$$\Psi_1$$
=exergy at inlet

 Ψ_1 =exergy at outlet

Exergy efficiency of complete turbine is given by the

$$\eta_T = \eta_H \times \eta_I \times \eta_L \tag{28}$$

C. Energy and exergy analysis condenser

The specifications and operating parameters of condenser are given in table 15 and 16.

Table 15.Specification of condenser

Туре	Surface type made of fabricated single head
Area	96.55cm ²
Cooling water flow rate	24250 TPH

1) Energy analysis of condenser: Energy entered in the condenser in the form wet steam.

Table 16.Parameter used for the efficiency calculation of condenser					
Parameters	Unit	Inlet	Outlet		
Mass flow	TPH	513.243	589.60		
Pressure	Bar	0.1013	0.1013		
Temperature	Celsius	46.7	46.01		
Enthalpy	kj/kg	2586.4016	192.57		
Entropy	kj/kg-K	8.1502	0.6516		
Exergy	kj/kg	95.23	7.03		
Cooling tower					
Temperature	Celsius	36	42.2		
Water flow	TPH	32000	32000		

The energy analysis of condenser can be calculated by using equation 29, 30 and 31 respectively [12]. Mass balance of condenser is

Energy loss =
$$m_{in}(h_{in} - h_{out}) - Q_K$$

First law efficiency of condenser is given by the formula

$$\eta_1 = \frac{Q_K}{m_{in}(h_{in} - h_{out})}$$
(30)

$$Q_k = mC_p dt \tag{31}$$

m= water flow in the cooling water

 m_{in} = water inlet in condenser

Qk=heat loss in condenser

hin= enthalpy of inlet saturated steam



h_{out}= enthalpy of out let condensate water dt= terminal temperature difference of cooling tower

2) *Exergy analysis of condenser :*Exergy out from the condenser is the form of condensate water.

The exergy analysis of condenser can be calculated by using equation 32, 33 and 34 respectively [12]. Mass balance of condenser is given by

$$T_o S_{gen} = m_{in} \left(\Psi_{in} - \Psi_{out} \right) - \Sigma Q_{in} \left(1 - \frac{T_0}{T_{out}} \right)$$
(32)

2nd law efficiency of condenser is given by the formula

$$\eta_{II} = 1 - \frac{I_{destroyed}}{m_{in}(\Psi_{in} - \Psi_{out})}$$

$$(33)$$

$$\eta_{II} = \frac{\mathcal{Q}_{in} \left(\mathbf{1} - \frac{T}{T_{out}} \right)}{m_{in} \left(\Psi_{in} - \Psi_{out} \right)} \tag{34}$$

 T_{out} =temperature at the outlet of condenser

 Ψ_{in} = exergy inlet in the condenser

 Ψ_{out} = exergy inlet in the condenser

D. Energy and exergy analysis pump

The specifications and operating parameters of condenser are given in table 17 and 18.

Table 17Specification of CEP pump

Type of motor	Induction type
Speed	1483rpm
Power	325 kw
Quantity	3

Parameters	Unit	Inlet	Outlet
Mass flow	TPH	589.60	589.60
Temperature	Celsius	46.01	46.11
Pressure	КРа	10.1302	1919.16
Enthalpy	kj/kg	192.5741	194.6527
Entropy	kj/kg-K	0.6516	0.6522

Table 18Parameter used for the calculation of CEP efficiency

E. Energy analysis of pump

Energy entered by the pump in the form of power of electric motor. The energy analysis of pump can be calculated by using equation 31and 32 respectively [12].

$$\eta_p = \frac{h_{2s} - h_1}{h_{2a} - h_1}$$

Exergy analysis of pumpExergy out from the pump in the form pressurized water.

ActualWork

1)

(35)

Exergetic efficiency
$$= \frac{\text{Exergy Recovered}}{\text{Exergy Supplied}}$$

$$\eta_{II} = 1 - \frac{T_{\circ}S_{gen.}}{h_2 - h_1}$$

(36)

III. RESULT AND DISCUSSION

A. Results for the energy and exergy analysis of boiler

The energy analysis of the boiler can be carried out by using the equation 1, 2, 3, 4, 5, 6 and 7 are as follows: Unburnt carbon loss

$$L_1 = \frac{0.006192 \times 8077.8 kj / kg \times 100}{4000 kj / kg}$$

heat loss due to Unburnt Carbon=1.2504%

Dry flue gas loss

$$L_2 = \frac{6.81 \times 0.23 \times (140 - 32) \times 100}{4000}$$

heat loss due to dry flue gases = 4.2298%

Loss due to moisture in fuel

$$L_3 = \frac{0.15 \times [584 + 0.23(140 - 32)]}{4000} \times 100$$

Heatlossdue to the Mositurein fuel= 2.2831%

Loss due to hydrogen in fuel

$$L_4 = \frac{9 \times 2.84 \times 584 + 0.23(140 - 32)}{4000} \times 100$$

Heat loss due to hydrogen in fuel = 3.8905%

Loss due to moisture in air

$$L_5 = \frac{6.8521 \times 0.0204 \times 0.43(140 - 32) \times 100}{4000}$$

Heatloss due to moisture in air = 0.1698%

Loss due to radiation

$$L_6 = 0.548 \times \left[\left(\frac{352}{55.55} \right)^4 - \left(\frac{305}{55.55} \right)^4 \right] + 1.957 \times \left(352 - 305 \right)^{1.25} \sqrt{\frac{196.85 \times 3.5 + 68.9}{68.9}}$$

heat loss due to Radition = 0.1909%

Heat loss due to unmeasured loss in boiler

 $L_7 = 0.8700$

Total losses= 1.2504+4.2298+2.2831+3.8905+0.1698+0.1909+0.8700

= 12.8845%

Boiler efficiency = 100 - 12.8845%

The results for the exergy analysis of boiler carried out by using equation 8, 9, 10, 11, 12, 13 and 14 are as follows: Exergy of fuel

 $\varepsilon_{f} = 34183.16 \times 0.4058 + 21.95 \times 0.0076 + 11659.9 \times 0.0284 + 18242.90 \times 0.0035 + 13265.9 \times 0.0711$

$$\varepsilon_f = 15209.89 k j / k g$$

Total Exergy of fuel = 591.36MW

Exergy of feed water

 $\varepsilon_{\omega} = 4.178 [(519 - 305) - 305 \times l_n (519/305)]$

$$\varepsilon_{\omega} = 216.68 kj / kg$$

Total exergy of feed water = 44.588MW

Exergy of air supply

 $\varepsilon_a = 1.005 \left[(413 - 305) - 305 l_n \left(\frac{413}{305} \right) \right]$ $\varepsilon_a = 15.6169 kj / kg$ Total exergy of air supplieded = 3.6851MW $\varepsilon_s = (3416.57 - 113.295) - 305 (6.4906 - 0.395)$ $\varepsilon_s = 1444.117 kj / kg$ Total exergy of steam = 297.156MW

Exergy of flue gas

 $\varepsilon_{g} = 1.321 [(413 - 305) - 305l_{n} (413/305)]$ $\varepsilon_{g} = 20.533 kj / kg$

Total exergy of flue gas = 6.2739MWExergy efficiency (2nd law efficiency) of boiler

total exergy leaving the boiler

Exergy efficiency of boiler= 47.43%

Table 19 comparesion of energy and exergy analysis of boiler

	Result	
1	Energy	87.11%
2	Exergy	47.43%

B. Results for the energy and exergy analysis of turbine

The results for the energy analysis of turbine by using equation 15, 16, 17 and 18 are as follows:

1) Energy efficiency of HP Turbine

$$\eta_1 = \frac{3416.57 - 3080.8621}{3416.57 - 3028.5129}$$

EnergyefficiencyHPT(η_1) = 86.50%

2) Energy efficiency of IP Turbine

$$\eta_1 = \frac{3530.17 - 3051.92}{3530.17 - 3003.01}$$

Energy efficiency of IPT $(\eta_1) = 90.72\%$

3) Energy efficiency of LP Turbine

$$\eta_1 = \frac{3051.92 - 2585.23}{2051.02 - 2585.23}$$

Energy efficiency of LPT (η_1) = 63.30%

Sr. No.	Components	Value
1.	High Pressure Turbine(HPT)	86.50%
2.	Intermediate Pressure Turbine(IPT)	90.72%
3.	Low Pressure Turbine (LPT)	63.30%

The energy efficiency of total turbine is given by the

 $\eta_T = 0.8650 \times 0.9072 \times 0.6330$

Totalenergyefficencyof turbine $(\eta_T) = 49.63\%$

The results for the exergy analysis of turbine by using equation 19, 20, 21, 22, 23, 25, 26, 27 and 28 are as follows: *a) Exergy efficiency of HP Turbine*

$$\eta_{II} = 1 - \frac{300 \times (6.2397 - 6.0956)}{(1474 \cdot .598 - 1132 \cdot .206)}$$

Exergy efficiency of HPT(η_{II}) = 87.16%

b) Exergy efficiency IP Turbine

$$\eta_{II} = 1 - \frac{300 \times (6.9043 - 6.8166)}{(1371 . 898 - 867 . 343)}$$

Exergy efficiency of IPT(η_{II}) = 94.69 %

Exergy efficiency of LP Turbine

Formula used for

c)

$$\eta_{II} = 1 - \frac{300 \times (6.9043 - 7.7516)}{(867.343 - 146.458)}$$

Exergy efficiency of LPT(η_{II}) = 64.15%

TT 1 1 01	-	cc .	c	1.00			C . 1 *	
Table 21	Exerge	efficiency	ot	different	com	ponents.	of furbin	e
1 4010 -1		•••••••	· · ·		• • • • • •	ponentos	01 001 011	•

Sr. No.	Components	Value
1.	High Pressure Turbine(HPT)	87.16%
2.	Intermediate Pressure Turbine(IPT)	94.69%
3.	Low Pressure Turbine (LPT)	64.15%

 $\eta_T = 0.8716 \times 0.9469 \times 0.6415$

Totalenergyefficencyof turbine(η_T) = 52.33%

|--|

	RESULTS	
1	Energy	49.63%
2	Exergy	52.33%

C. Results for the energy and exergy analysis of condenser

The results for the energy analysis of condenser can be calculated by using equation 29, 30 and 31 are as follows:

$$\eta_1 = \frac{32000 \times 4.178 \times (315.2 - 309)}{589.60(2586.4016 - 192.57)}$$

Energyefficiency of condenser $(\eta_1) = 59.67\%$

The results for the exergy analysis of condenser calculated by using equation 32, 33 and 34 are as follows:

$$\eta_{II} = \frac{32000 \times 4.178 \times (315.2 - 30) \left(1 - \frac{30}{315.2}\right)}{589.60 \left(95.23 - 7.03\right)}$$

Exergy efficiency of condenser =32.40%

Table 23. Comparison of Energy and exergy analysis of condenser

	Result	
1.	Energy	58.89%
2.	Exergy	34.69%

D. Results for the energy and exergy analysis of pump

The results for the energy analysis of pump by using equation 35 are as follows:

$$\eta_p = \frac{194.5306 - 192.5741}{194.6527 - 192.5305}$$
$$\eta_p = 94.56\%$$

The results for the exergy analysis of pump by using equation 36 are as follows:

$$\eta_{II} = 1 - \frac{305(0.6522 - 0.6516)}{194.6522 - 192.5741}$$

$$\eta_{II} = 91.19\%$$

Table 24. Comparison	of energy and	exergy analysis of CEP p	oump

Result			
1.	Energy	94.56 %	
2.	Exergy	91.19%	

IV. CONCLUSION

This study presents the energy and exergy analysis of 250 MW Panipat coal thermal power plant. The temperature and pressure of main stream and the condenser pressure are considered as operating parameters. From the study it is observed that the major contribution of energy efficiency is found in pump of 94.56% followed boiler of about 87.11% and condenser of 59.67%. The major exergy efficiency is found in the pump of 91.19% followed by turbine of 52.33% and condenser of 32.40% of the total exergy supplied.

REFERENCES

 $[1]. http://www.hpgcl.org.in/powerplants_3.hp$

 $[2]. \qquad http://www.hpgcl.org.in/aboutus_1.hp$

[5]. Nighot, S.V., Mr.Shende, A.S., Raghorte, G.S., Prof.Dongre, S.S., and Umak, V.V., (2017), "Study of boiler and thermal power plant station." International Journal on Research and Modern Trends in Engineering & Management (IJRMTEM), Vol.- 2, Issue-1

^{[3].} Cengel Y.A., Michael A. "Thermodynamics an engineering approach". New Delhi; Tata MaGraw Hill: 2006

^{[4].} Jegadeswaran, M.A., Daniel V.S., and Kanna, G.T., (2015), "Analysis for efficiency improvement and fuel savings opportunities in thermal power plant." International journal of science and technology, Vol. -3, pp: 9-15.

- [6]. Kumar, K., and Rao, G.S., (2013), "Performance analysis from the energy audit of a thermal power plant." International Journal of Engineering trends and Technology, vol. - 4, pp: 2485-2490.
- [7]. Kurklya, R., and Chaudhary, S., (2012) "Energy analysis of thermal power plant." International journal of scientific and engineering research, Vol.-03, pp: 1-7.
- [8]. Ishan, P. Bhatt., and Panchal,C.P., (2016), "Improved Efficiency of Boiler Plant withDifferent GCV and Carbon Percentage." International Advanced Research Journal in Science, Engineering and Technology, Vol. - 3, pp: 126-129.
- [9]. Hada, P.S., and shah, J.H., (2012), "First law and second law analysis of a lignite fired boiler used in a 30MWe Thermal power plant." International journal of engineering and innovative technology, Vol.-1, pp: 84-88
- [10]. Pal, M.K., Kumar, A., and Chandra, H., (2013), "Energy and Exergy analysis of boiler and turbine of coal fired thermal power plant." International Journal of Engineering Research and Technology, vol. -2, pp: 1428-1440.
- [11]. Goyal, v., and Dang, R.,Dondapati, R., and Mangal, S.K., (2014), "Exergy Analysis of a 210 MW unit at 1260MW thermal plant in India." 2014 second international conference on artificial intelligence, modelling & simulation, pp:228-231.
- [12]. Kaushik, S.C., Reddy V.S., and Tyagi, S.K., (2011), "Energy and exergy analyses of thermal power plants: A Review", Renewable and Sustainable Energy Reviews, vol. 15, pp. 1857-1872.
- [13]. Nag P K., "Engineering Thermodynamics". New Delhi; Tata MaGraw Hill: 2006.

45.98

IMPACT FACTOR: 7.129

INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089 🕓 (24*7 Support on Whatsapp)