



# INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Volume: 7 Issue: IV Month of publication: April 2019

DOI: https://doi.org/10.22214/ijraset.2019.4134

www.ijraset.com

Call: © 08813907089 E-mail ID: ijraset@gmail.com



ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 6.887

Volume 7 Issue IV, Apr 2019- Available at www.ijraset.com

### To Study the Effect of Mixture of Natural and Chemical Coagulant on Water Treatment

Akshay Pawar<sup>1</sup>, Mahesh Solanke<sup>2</sup>, Vaibhav More<sup>3</sup>, Vikas Sanap<sup>4</sup>, Saif Momin<sup>5</sup>, S.C. Tandale<sup>6</sup>

1, 2, 3, 4, 5</sup> Student, Civil engineering department, KJEI'S TAE, Pune, India

6Assistant Professor, Civil engineering department, KJEI'S TAE, Pune, India

Abstract: The present study was carried out to confirm the effectiveness of moringa seed powder extracted from mature-dried moringa oleifera and watermelon seed powder which are commonly available in most rural communities for water treatment. The main objective of this work is to evaluate the efficiency of mixture of natural and chemical coagulants in treating water sample. During this study, surface water samples are collected for treatment by mixing moringa seeds, watermelon seeds in powdered form with alum, resulting in an effective natural clarification agent for water treatment. Various doses of moringa seed, watermelon seed powder with varying percentage by weight of alum were taken and checked for the efficiency dose on sample water. Application of this low cost moringa oleifera seeds and watermelon seeds recommended for eco-friendly, Nontoxic, simplified water treatment where rural and semi-urban people living in extreme poverty.

Keywords: Alum, Coagulation, Moringa Oleifera Watermelon seed

#### I. INTRODUCTION

Moringa Oleifera is a tropical multipurpose tree that is commonly known as the miracle tree. Among many other properties, M. Oleifera seeds contain a coagulant protein that can be used either in drinking water or wastewater treatment. It is said to be one of the most effective natural coagulants and the investigation on these kinds of water treatment agents is growing nowadays because of their low cost. Watermelon seed has high potential of water treatment by using it in coagulation process. Watermelon seed is a possible replacement for alum and other polyelectrolytes in treating Water. Alum (aluminium sulphate) is widely used for water treatment but it produces high volume of non-biodegradable sludge which cannot be treated properly and had adverse impact on surrounding environment.

#### II. PROBLEM STATEMENT

However, recent studies have raised doubts about advisability of introducing aluminium into the environment especially concerning about residuals in the treated water large production of sludge volume and Alzheimer's diseases. There is also another problem of alum's reaction with natural salinity present in water leading for reduction of PH and low efficiency in coagulation in cold water. Ferric salts and synthetic polymers have been used as alternatives but those chemicals can be seriously problem becomes many developing country can hardly afford costs as well as low availability of such chemicals for water and waste water treatment. Natural macromolecular coagulants shows bright future and are concerned by many researchers because their abundant source, low price, inequity, multifunction and biodegradation. An easy way to comply with IJRASET paper formatting requirements is to use this document as a template and simply type your text into it.

#### III. METHODOLOGY

#### A. General

Experiments are carried out in the laboratory on Moringa Oleifera, Watermelon seed and alum. All coagulation experiments are carried out using collected turbid water. A flocculator jar test apparatus is used in this experiment to coagulate sample of collected turbid water using coagulants.

#### B. Materials

The materials used in this study are natural coagulants as Moringa Oleifera, watermelon seed. Also a chemical coagulant such as alum is used.

#### C. Collection Of Sample

The water sample is collected from Khadakwasla Dam.



#### International Journal for Research in Applied Science & Engineering Technology (IJRASET)

ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 6.887 Volume 7 Issue IV, Apr 2019- Available at www.ijraset.com

#### D. Preparation Of Natural Coagulants


Seeds of moringa oleifera are collected and allow to dry for several days and then powder is made from that seeds. Same process is done for watermelon seed.

- E. Tests On Water
- 1) pH test.
- 2) Turbidity test.
- 3) Jar test.
- F. Test Procedure.
- 1) Firstly the pH test is carried out by using pH meter on the sample water for determination of pH.
- 2) Then the turbidity of water sample is determined by using digital turbimeter.
- 3) Determination of optimum alum dosage by using Jar test.
- 4) Determination of optimum M.O. dosage by using Jar test.
- 5) Determination of optimum watermelon seed dosage by using Jar test.
- 6) After taking out optimum dosage of alum, MO and watermelon seed powder the analysis of mix dosage is done. Then by considering various proportions the same tests are repeated with these proportions. Results came by these tests gives the most efficient mix dosage of chemical and natural coagulation for the treatment of collected water sample.
- 7) Then by taking the varying proportions of the natural and chemical coagulants the jar tests are carried out to get the optimum dosage of the coagulant.

#### IV. RESULTS AND DISCUSSIONS

#### A. Jar Test Results Of Alum Dosage For Collected Water Sample

Sample	Alum	Initial	Final	Initial	Final
No.	Dosage	Turbidity	Turbidity	pН	pН
	(Mg/lit.)	(NTU)	(NTU)		
1	5	11.1	1.8	6.81	5.56
2	10	11.1	1.2	6.81	5.60
3	15	11.1	1.0	6.81	5.58
4	20	11.1	0.4	6.81	5.68
5	25	11.1	1.1	6.81	5.47
6	30	11.1	1.9	6.81	5.09



Graph 1

The most effective optimum dosage for alum observed is 20mg/lit.




ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 6.887 Volume 7 Issue IV, Apr 2019- Available at www.ijraset.com

#### B. Jar Test Results Of Mo Seed Powder Dosage For Collected Water Sample

Sample	Moringa	Initial	Final	Initial	Final
No.	oleifera	Turbidity	Turbidity	pН	pН
	(Mg/lit.)	(NTU)	(NTU)		
1	25	11.1	2.9	6.81	7.32
2	50	11.1	2.7	6.81	7.14
3	75	11.1	1.7	6.81	7.54
4	100	11.1	2.8	6.81	7.61
5	125	11.1	3.6	6.81	7.29
6	150	11.1	4.2	6.81	7.95

Table 2



The most effective optimum dosage for Moringa Oleifera observed is 75mg/lit.


#### C. Jar Test Results Of Watermelon Seed Powder Dosage For Collected Water Sample

Sample	Watermelon	Initial	Final	Initial	Final
No.	Powder	Turbidity	Turbidity	pН	pН
	(Mg/lit.)	(NTU)	(NTU)		
1	25	11.1	5.3	6.81	6.46
2	50	11.1	6.6	6.81	6.89
3	75	11.1	6.9	6.81	6.94
4	100	11.1	7.5	6.81	6.97
5	125	11.1	8.1	6.81	6.89
6	150	11.1	8.8	6.81	6.91

Table 3

#### International Journal for Research in Applied Science & Engineering Technology (IJRASET)

ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 6.887 Volume 7 Issue IV, Apr 2019- Available at www.ijraset.com



The most effective optimum dosage for Watermelon Powder observed is 20mg/lit.

#### D. Mix Proportion Results Of Watermelon, Alum And Mo Powder

In the following results the proportion is decided on the basis of maximum optimum amount of dosage of Mo, i.e. 75 mg/lit. Following four different proportions are used to find minimum turbidity of collected sample:

Alum	:	Wat	ermelon	:	MO	
1	:		1	:	1	
	0.5	:	1		:	1
	0.5	:	0.5		:	1
0.5			1		0.5	

Initial Turbidity of water sample: 11.1 NTU.

Sample	Alum	Watermelon	Moringa	Initial	Final	Final
No.	(mg/lit)	seed	Oliefera	pН	pН	Turbidity
		(mg/lit)	(mg/lit)			(NTU)
1	25	25	25	6.81	6.56	0.9
2	15	30	30	6.81	6.22	0.7
3	18.75	18.75	37.5	6.81	6.37	0.2
4	18.75	37.5	18.75	6.81	5.89	0.5

Table 4

The most effective proportion for mixture of coagulants observed is 0.5: 0.5: 1.

#### E. Result Of Jar Test On High Turbid Water

A sample of sewage water is collected from a Nallah near Rajaram Bridge. This water sample is very turbid having turbidity of 84.7 NTU. Then this collected sample is allowed to settle down for 12 hours. pH occurred of collected sample is 7.4 which is Normal pH range. Then Jar test is performed on this collected sample by adding most efficient proportion of natural coagulants and chemical coagulant, i.e. alum, gram and MO. In the following results the proportion is decided on the basis of maximum optimum amount of dosage of Mo, i.e. 75 mg/lit.

The initial turbidity of water is 84.7 NTU.



#### International Journal for Research in Applied Science & Engineering Technology (IJRASET)

ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 6.887 Volume 7 Issue IV, Apr 2019- Available at www.ijraset.com

Alum : Watermelon : MO

0.5 : 0.5 : 1

Alum	Watermelon	Moringa	Initial	Final	Final
(mg/lit)	seed	Oliefera	pН	pН	Turbidity
	(mg/lit)	(mg/lit)			(NTU)
18.75	18.75	37.5	7.4	6.42	5.3

Table 5

In the following results the proportion is decided on the basis of maximum optimum amount of dosage of Mo, i.e. 50 mg/lit.

Alum : Watermelon : MO

Alum	Watermelon	Moringa	Initial	Final	Final
(mg/lit)	seed	Oliefera	pН	pН	Turbidity
	(mg/lit)	(mg/lit)			(NTU)
12.5	12.5	25	7.4	6.92	10.8

Table 6

#### V. CONCLUSION

From the analysis of results obtained it is observed that the mixture of natural coagulants, i.e. powder of MO seed and watermelon seed powder with the chemical coagulant, i.e. alum is very productive. Use of alum can be reduced in large extent by adding MO and Watermelon seed powder. 0.5: 0.5: 1 for 75mg/lit is the most effective proportion of Alum, watermelon seed powder and MO for the low turbid, medium turbid and high turbid water. Mixture of MO powder and watermelon seed powder also effects on pH of water and turns it to the range of potable water, i.e. 6 to 7.5. It is also observed that these natural coagulants attracts flocks and helps in reducing setting time of flocks in turbid water. For the small water treatment plant the use of mixture of natural and chemical coagulant is most efficient than the use chemical coagulants only. This is the most suitable method to treat water in regions where MO and Watermelon seeds are available in large extent such as South Asian region.

#### VI. ACKNOWLEDGEMENT

We would like to express our gratitude towards guide Prof.S.C.Tandale for his constant encouragement and valuable guidance during the completion of the project. We are very thankful Prof. S.S. Deshmukh (H.O.D) Civil department for his valuable cooperation and guidance during the project work. We would to like to thank our Principal Dr. Nilesh Uke for their constant encouragement, help during the course of our studies. We take this opportunity to thank all those who are directly involve in for their co-operation and their helpfulness during this project.

#### REFERENCES

- [1] Fuglie, L.J., 2001. The Miracle Tree. The Multiple Attributes of Moringa. Technical Centre for Agricultural and Rural Cooperation, 2001.
- [2] Ndabigengesere, A., Narasiah, K.S., 1998b. Use of Moringa oleifera seeds as a primary coagulant in wastewater treatment.
- [3] Environmental Technology 19 (8), 789–800. [4] Sciban, M., Klasnja, M., Antov, M., Skrbic, B., 2009. Removal of water turbidity by natural coagulants obtained from chestnut and acorn. Bioresource Technology 100 (24), 6639–6643.
- [4] I.M. Muhammad, S. Abdulsalam, A. Abdulkarim & A.A. Bello Water Melon Seed as a Potential Coagulant for Water Treatment
- [5] Eman N. Ali, Suleyman A. Muyibi, Hamzah M. Salleh, Mohd Ramlan M. Salleh and Md Zahangir Alam Moringa oleifera seeds as natural coagulant for water treatment Thirteenth International Water Technology Conference, IWTC 13 2009, Hurghada, Egypt.
- [6] Mangale Sapana M., Chonde Sonal G. and Raut P. D Use of moringa oleifera (drumstick) seed as natural absorbent and an antimicrobial agent for ground water treatment. Research Journal of Recent Sciences ISSN 2277-2502 Vol. 1(3), 31-40, March (2012) International Science Congress Association
- [7] S.N. Ugwu, A.F. Umuokoro, E.A. Echiegu, B.O. Ugwuishiwu and C.C. Enweremadu. Comparative study of the use of natural and artificial coagulants for the treatment of sullage (domestic wastewater) Cogent Engineering (2017) civil & environmental engineering research article 24 August 2017









45.98



IMPACT FACTOR: 7.129



IMPACT FACTOR: 7.429



## INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call: 08813907089 🕓 (24\*7 Support on Whatsapp)