



IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Volume: 3 Issue: IV Month of publication: April 2015 DOI:

www.ijraset.com

Call: 🛇 08813907089 🕴 E-mail ID: ijraset@gmail.com

International Journal for Research in Applied Science & Engineering Technology (IJRASET) Elimination of Leakage Current in PV Based

Current Source Inverter

R.Manivannan^{#1}, P.Nammalvar^{*2}

^{#1}UG scholar, ^{*2}Associate professor, Department of EEE, IFET College of Engineering, villupuram, Tamil nadu, India

Abstract: This paper deals with the implementation of four leg inverter to eliminate the earth leakage current. In the PV based system, some amount of leakage current induces on the inverter output terminals due to high switching frequency and electromagnetic interface problem, which inject the leakage current into output load side. To eliminate the leakage current in the conventional system an isolation transformer can be used. This increase the cost and size of the system and reducing the overall efficiency and lifespan of the inverter. An implementation of four leg inverter in solar power system the leakage current can be eliminate through neutral coupling system. There by increasing efficiency and lifespan of inverter. The effectiveness of this proposed system was verified through MATLAB simulation and small scale prototype model.

Index Terms— Transformerless CSI Inverter, Common Mode Leakage Current, SV - PWM.

I. INTRODUCTION

In the world, Renewable energy sources become a more and more important contribution to the total energy production. Today the solar energy production is very low as compared to the other renewable energy sources, but the PV systems are one of the fastest growing in the world. The price of PV system components is high, but especially the PV modules are decreasing and the market for PV system is expanding with high rate of rapidly. Solar power will be dominant because of its availability and reliability also. Photovoltaic inverters become more and more wide range of spread within both private and commercial circles.

In this paper, four legs are used to design a proposed system and the parallel connection between DC link inductors and DC link capacitor build in same core of inverter.

- A. Addition of the fourth leg to avoids the possibility of undesirable current flow through neutral (or) any phases during zero state condition [2]. Series split capacitor arrangement and connects of neutral midpoint of split capacitor eliminating high frequency component from common mode voltage. This in terms restricts the flow of common mode leakage current [7].
- *B.* Introduction of common mode inductor in DC link of high impedance to flow of common leakage current. The space vector pulse width modulation (SV-PWM) technique is used to producing gate pulse to IGPT switches in proposed inverter.

In the conventional system, three phase PWM CSI requires intermediate isolation transformer need to eliminate leakage current at output side [1]. So the use of transformer reduces 2-3% efficiency of the system. a modified CSI is proposed in this paper. It eliminates the high-frequency component in the common mode voltage, thereby suppressing the common mode earth leakage current.



II. MODIFIED THREE-PHASE FOUR LEG INVERTER

The proposed four leg inverter consist of PV module is connected across the input dc capacitors. The dc-link is realized by the two

www.ijraset.com IC Value: 13.98

Volume 3 Issue IV, April 2015 ISSN: 2321-9653

International Journal for Research in Applied Science & Engineering Technology (IJRASET)

capacitors are connected in series. Midpoint of these capacitors is connected to the neutral of the overall .DC-link inductors Ldc1 and Ldc2 are wound on the same core and therefore have a high value of mutual coupling. To generate ac current waveforms from the dc current, eight semiconductor switching devices are used. Each device has unidirectional current flow capability and can block the reverse voltage [2]. Either a diode connected in series with IGBT or reverse blocking (RB) IGBTs can be used to realize these switches. Output of three phases is connected to the load side through capacitor–inductor (C–L) filter and the fourth leg is connected to the neutral of the system as shown in Fig. 2.2. Components of the proposed inverter and their role in suppressing the earth leakage current are discussed below:

EXISTING SYSTEM:



Fig.2.1 Existing three leg inverter





Fig.2.2 Proposed four leg inverter

A. Common Mode Inductor

Earth leakage current is a common mode nature and flows through both the -ve and +ve terminals of dc-link to the earth. Therefore, to reduce this current, common mode inductor is connected in the +ve and -ve dc-link. This inductor offers high impedance to the leakage current and reduces its magnitude. However, this addition does not eliminate the common mode voltage completely.

B. Split Capacitor DC-Link

Split capacitor dc-link is realized by connecting two capacitors in series. Midpoint of the link is connected to the system neutral [3]. During operation, dc-link voltages vdc1 and vdc2 are maintained almost constant. Therefore, voltage difference between PV terminals and neutral wire is a constant dc value without high frequency ac. Since neutral point is earthed at the substation, voltages across Cp1 and Cp2 are almost dc \without high-frequency ac. Therefore, no high-frequency earth leakage current would flow. This technique is being used in VSI systems also, but where split capacitor arrangement is used to reduce the leakage current. However, in CSI, this arrangement results in undesirable inverter currents during the "zero state."

International Journal for Research in Applied Science & Engineering Technology (IJRASET)

C. Fourth Leg

Fig. 2.3 shows the reference waveform for inverter ac currents. The complete cycle is divided into six sectors. In sector-I, current reference for phase-A and phase-C is positive and that for phase-B is negative. To realize these reference currents, switches SA+, SA-, SB+, SB-, SC+, and SC- are modulated shows the current waveforms during a sampling period in sector-I. Solid lines are the average phase currents, and dotted lines indicate the instantaneous currents.



SWITCHES **S1 S2 S**3 **S**4 **S**5 **S6** N1 N2 0-60 ON OFF OFF OFF OFF OFF ON ON ON OFF OFF OFF ON 60-120 ON OFF OFF 120-180 OF ON ON OFF OFF OFF OFF ON 180-240 OFF OFF ON ON OFF OFF OFF ON OFF OFF 240-300 OFF OFF ON ON ON OFF 300-360 OFF OFF OFF OFF ON ON OFF ON

Fig.2.4. Switching states for proposed system



Fig 2.5 Current flow during zero state in(a) conventional CSI and (b) CSI with Split capacitor.

In the existing three leg current source inverter, the current flowing through phase-B and neutral during the zero state. Fig. 2.5(b) shows the flow of this additional current when phase-B voltage is negative. Due to current flow in phase B during the zero state, average value of current during the sampling period deviates from the desired value as shown in Fig. 2.5(b). This current flow during the zero state is undesirable and should be restricted [1]. In order to eliminate the flow of this current, additional pair of switches SN+ and SN- are connected across the dc-link. Midpoint of this new leg is connected to the neutral. For the zero state,

www.ijraset.com IC Value: 13.98

International Journal for Research in Applied Science & Engineering Technology (IJRASET)

instead of closing both switches of a particular phase, these switches are closed. Therefore, no current flows from any phase to neutral during this duration.

D. Space Vector Pulse Width Modulation

The main objectives of space vector pulse width modulation generated gate pulse are the following.

- *1)* Wide linear modulation range.
- 2) Less switching loss.
- 3) Less total harmonic distortion in the spectrum of switching waveform Easy implementation and less computational calculations.



Fig 2.6 Space Vector Diagram

one of the three top switches carry *idc*, and one of the three bottom switches carry *idc*at any time. Since dc link current is same in both topologies (for same power delivered), total conduction losses remain same[7].

Switching losses: Since dc link current is same in both topologies, switching losses in CSI depend on the voltage appearing across the switch during turn-on and turn-off. Fig. 2.6(a) and (b) shows the switching states in conventional and four-leg Fig. 2.6. Space vector diagram for (a) conventional and (b) proposed fourleg CSI, respectively. Switching transitions in sector 1 for both the schemes are

Conventional CSI: $(a+a-) \rightarrow (a+b-) \rightarrow (a+c-) \rightarrow (a+a-)$

Proposed 4 – leg CSI: $(n+n-) \rightarrow (a+b-) \rightarrow (a+c-) \rightarrow (n+n-)$.

The transition $(a+b-) \rightarrow (a+c-)$ is same for both the circuits, and hence there will not be any difference in the losses for this transition. Consider the switching transition $(a+a-) \rightarrow (a+b-)$ in conventional CSI and the switching transition $(n+n-) \rightarrow (a+b-)$ in four-leg CSI. In conventional CSI, there is only one transition $(a-\rightarrow b-)$, and its loss is proportional to the line voltage *Vab* appearing across the switches. In case of four-leg CSI, there are two transitions at this instant $(n+\rightarrow a+)$ and $(n-\rightarrow b-)$, and the switching loss depends on phase voltages *Van* and *Vnb* appearing across the switches at that instant, respectively [8]. As *Van* and *Vnb* are positive in this sector, instantaneous value of *Vab* is equal to the sum of instantaneous values of *Van* and *Vnb*. Therefore, loss in conventional CSI for transition $(a-\rightarrow b-)$ is approximately equal to the sum of losses in proposed CSI for transitions $(n+\rightarrow a+)$ and $(n-\rightarrow b-)$. Similarly, loss in conventional CSI for transition $(a+c-) \rightarrow (a+a-)$ is equal to loss in proposed CSI for transition $(a+c-) \rightarrow (n+n-)$. The total switching loss in conventional and four-leg CSI is approximately same. In case of four-leg CSI, losses are distributed over more number of devices than that in conventional CSI.

IV. SIMULATION AND RESULTS

Simulations were performed by using MATLAB-Simulink to verify that the proposed PV based current source inverter can be practically implemented in power applications such as solar power generation, etc. It helps one to confirm the SV PWM switching

www.ijraset.com IC Value: 13.98

International Journal for Research in Applied Science & Engineering Technology (IJRASET)

strategy can be implemented for the proposed topology. Then, this strategy is implemented in a real time environment, i.e., to produce SV PWM switching signals for the switches. The following figures and data are given from the simulated results of proposed topology.

PARAMETER FOR SIMULATION

| Values |
|--------|
| 5 mh |
| 650 µf |
| 400mh |
| 1.3 mh |
| |
| 5600µf |
| 142 V |
| |

Table No 3.1 Parameters For Simulation

A. Simulation Circuit



Fig 3.1 simulation Circuit





International Journal for Research in Applied Science & Engineering Technology (IJRASET)







V. HARDWARE DEVELOPMENT

This hardware development describes in detail of the hardware components, which consist of control circuit and driver circuit for hybrid system. The hybrid system having three trigging circuit and Tone controller taken so on. The control circuit is the PIC microcontroller circuit which generates the gate signals to the power circuit. The driver circuit is used to amplify the gate signals generated by the PIC microcontroller. The general structure of hybrid system is given below.

A. Proposed Hardware



Fig 4.1 Proposed Hardware

Volume 3 Issue IV, April 2015 ISSN: 2321-9653

International Journal for Research in Applied Science & Engineering

Technology (IJRASET) HARDWARE RESULTS



Fig 4.2 Inverter Input Voltage



Fig 4.3 Inverter Output Voltage



Fig 4.4 Inverter Neutral Voltage

HARDWARE PARAMETERS:

| Inverter Input voltage Vdc | = 10 volts |
|-----------------------------|-------------|
| Inverter output voltage Vac | = 11 volts. |
| Neutral voltage | = 11 mv. |

International Journal for Research in Applied Science & Engineering Technology (IJRASET)

| = 4.7 ohms. |
|-------------|
| = Vn/Rn. |
| = 11/4.7 |
| = 2.3 mA. |
| |

VI. CONCLUSION

In this proposed system, a four leg current source inverter can be implemented and the leakage current also eliminated through the neutral point of the proposed system in this paper. The simulation and hardware results are discussed in above and Where the THD value for output current was calculated as 3.49%.so the efficiency of this proposed system can be increased and also overall system size, cost can be reduced and lifespan of the proposed system increased through failure of equipment reduced. This proposed four leg current source inverter is very suitable for solar power generation for efficient utilization of solar energy.

REFERENCES

[1] Sandeep Anand, Saikrishna Kashyap Gundlapalli, and B. G. Fernandes, "Transformer-Less Grid Feeding Current Source Inverter for Solar Photovoltaic System,"IEEE Trans. Power Electron., vol., no. 10, oct 2014

[2] T. Kerekes, R. Teodorescu, P. Rodríguez, G. Vázquez, and E. Aldabas, "A new high-efficiency single-phase transformerless PV inverter topology,"IEEE Trans. Ind. Electron., vol. 58, no. 1, pp. 184–191, Jan. 2011.

[3] B. Mirafzal, M. Saghaleini, and A. K. Kaviani, "An SVPWM-based switching pattern for stand-alone and grid-connected three-phase singlestageboost inverters," IEEE Trans. Power Electron., vol. 26, no. 4, pp. 1102–1111, Apr. 2011.

[4] T. Kerekes, R. Teodorescu, P. Rodríguez, G. Vázquez, and E. Aldabas, "A new high-efficiency single-phase transformerless PV inverter topology," IEEE Trans. Ind. Electron., vol. 58, no. 1, pp. 184–191, Jan. 2011.

[5] P. P. Dash and M. Kazerani, "Dynamic modeling and performance analysis of a grid-connected current-source inverter-based photovoltaic system," IEEE Trans. Sustain. Energy, vol. 2, no. 4, pp. 443–450, Oct. 2011.

[6] E. Al-Nabi, B. Wu, N. R. Zargari, and V. Sood, "Sensorless control of CSC-fed IPM machine for zero- and low-speed operations using pulsating HFI method," IEEE Trans. Ind. Electron., vol. 60, no. 5, pp. 1711–1723, May 2013.

[7] B. Sahan, S. V. Araújo, C. Nöding, and P. Zacharias, "Comparativeevaluation of three-phase current source inverters for grid interfacing of distributed and renewable energy systems," IEEE Trans. Power Electron., vol. 26, no. 8, pp. 2304–2318, Aug. 2011.

[8] M. A. G. de Brito, L. Galotto, L. P. Sampaio, G. e Melo, and C. A. Canesin, "Evaluation of the main MPPT techniques for photovoltaic applications," IEEE Trans. Ind. Electron., vol. 60, no. 3, pp. 1156–1167, Mar. 2013.

[09] Y. Chen, K. Smedley, and J. Brouwer, "A cost-effective three-phase grid connected inverter with maximum power point tracking," in Conf. Rec. 41st IEEE IAS Annu. Meet., Tampa, FL, USA, Oct. 2006, vol. 2, pp. 995–1000.



R.Manivannan was born in Tamilnadu, India in 1993. He received his Diploma degree in Electrical and Electronics Engineering from Central polytechnic college, Chennai and he pursuing his B.E degree in Department of Electrical and Electronics Engineering at IFET College of Engineering, Villupuram, Tamilnadu 605108, India. His research interests are in the fields of power conversion in renewable energy sources and power generation.



P.Nammalvar was born in Tamilnadu, India in 1976. He received his B.E degree in Electrical and Electronics Engineering from Annamalai University, Chidambaram and M.E degree (Power Electronics & Drives) from Adhiparasakthi Engineering College, Melmaruvathur. He is currently employed as Associate Professor, in Department of Electrical and Electronics Engineering at IFET College of Engineering, Villupuram, Tamilnadu 605108, India. Currently, he is also working for a Ph.D. degree in the area of solar power conditioning.

His research interests are in the fields of renewable energy systems, Power factor corrections, DC/DC converters and Power Quality improvement. He is a life time member of ISTE.











45.98



IMPACT FACTOR: 7.129







INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089 🕓 (24*7 Support on Whatsapp)