



# **iJRASET**

International Journal For Research in  
Applied Science and Engineering Technology



---

# **INTERNATIONAL JOURNAL FOR RESEARCH**

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

---

**Volume: 9      Issue: III      Month of publication: March 2021**

**DOI: <https://doi.org/10.22214/ijraset.2021.33470>**

**[www.ijraset.com](http://www.ijraset.com)**

**Call:  08813907089**

**E-mail ID: [ijraset@gmail.com](mailto:ijraset@gmail.com)**

# Life Cycle Optimization of Residential Air Conditioner Replacement

N. Shiva Krishna<sup>1</sup>, Vijay Kumar<sup>2</sup>, Dr. M. Sreedhar Reddy<sup>3</sup>

<sup>1, 2, 3</sup>Department of Mechanical Engineering, Mallareddy college of engineering

**Abstract:** Cooling structures include a condenser to release extreme heat in the coolant and to transfer it outside. Throughout the condenser drift, the coolant flows is a basic feature of a condenser. As the contour includes several condensers, which retain heat from the air and the coolant temperature should be higher than the air. In this case, CFD and warm assessment support the hypothesis heat move through convection cooling by changing the condense volume. The test is performed on a smoke pressure cycle air-cooled tube condenser for the refrigeration structure. Copper alloy and aluminum alloy composites are the components used for tubing.

The coolants can be updated by R 12. The CFD evaluation is performed by distinguishing refrigerants to select temperature and heat movement speeds. The condenser is evaluated at warmth to evaluate the best content. 3D reveals in CREO and evaluation in ANSYS was conducted

**Keywords:** CFD, condenser, refrigeration, CREO, ANSYS.

## I. INTRODUCTION

An obligated air framework is the domestic contraction, device, or instrument that dehumidifies and distributes warmth from a region. (incessantly detached as AC.) The cooling takes place in a central cooling cycle. The "cooling" is a constant perspective of warming, airflow, and cooling. His motivation, whether in a contour or the vehicle, is to easily reach a cold climate.

### A. Air Conditioning System Basics And Theories

A main chart of the cooling period changed:

- 1) Rotation set,
- 2) Valve for growth,
- 3) Circle of the evaporators
- 4) Blower.

A bright siphon transfers heat from a lower thermal source through a higher-temperature heat sink during the refrigeration period. Warmth will normally flow the replacement way. This is the largest and most effective kind of refrigeration. A refrigerator is almost working when it siphons the glow from inside and to the room.

This cycle mixes up the way the stage shifts, where latent warmth is transferred during a fluid/gas phase change at a foreseen temperature and moves the pressing section of a non-adulterated material which furthermore vacillates its unanticipated development/limit. The ultimate result is reverse and the compartment is warmed by inserting the condenser within the compartment and the evaporator (which collects heat) (for example outdoors) or simply utilizing the usual coolant in the administering air design in a substitution manner.

That, in any event, if the outside air is under the edge of freezing into water (0 °C; 32 °F), is considered to all things to be sparkly siphon and it is valued for home warming to temperatures that satisfy. Chamber unloaders are a load control system that in business cooling systems is used at a fundamental level. On the semicircular fixed blower (or open) the heads may be equipped with unloaders that kill a touch of the blower's pile so that when maximum cooling is not required, it can function better. Electrical or mechanical unloaders can be.

Dampness Refrigeration equipment frequently decreases the air lightness of the device. The relatively cold evaporator circle (under the point of dew) joins water anger from the air above when the water simply accumulates from a bottle of a defilement drink. Water is supplied and the water is dissipated and its relative adhesiveness is eliminated from the cooled region. Since people exercise and refresh their skin daily by sweat, dryer air (decently) Refrigerant

## B. Types of air Conditioner Equipment



Fig.1; Air conditioning Equipment

## II. INTRODUCTION TO CONDENSOR


$$\epsilon = \frac{\text{Actual heat transfer}}{\text{Minimum } kJ/K \text{ between Hot and Cold} \times (T_{hot,in} - T_{cold,in})}$$


Fig.2; Heat transfer formula

The rate of the impetus for adequacy is measured. We must note that it is impossible to achieve 100% amplitude. The genius arrangements of the units will strengthen them in any situation. For eg, more condensers and evaporators in the ambient control system would have header allocation tubes for a coolant bay equally spaced out. Condenser Types:

- 1) Condenser evaporation
- 2) Condenser air cooling
- 3) Condenser for water cooling

## A. Evaporative Condenser




Figure 6-20.—Air-cooled condenser mounted on a compressor unit.

Fig.3; Air cooled Condensor

20°C difference between the dry bubble temperature entering and the temperature at the social gatherings is regularly unsurprising, as nearby condensers are ridiculous in gigantic words. Due to the lack of attendance of water diversion, corresponding simplicity of travel, and the independence from any prosperity risks associated with using sprinkled water, air-cooled condensers are growing reputably. One problem is that the limitation of the cooling plant is not diminishing gradually as the dry-bulb increases but prevents it from becoming blue as the strong squeezing factor is reduced. A fractured path must be taken to prepare for a blower section to be unloaded as the uniting strain increases until it appears at the point of cutting. The operation at a decreased cutoff will then be continued beyond the dry-bulb surrounding arrangement. It is a reasonable way of choosing air-cooled condensers to operate a few degrees higher than the setup for the rest of the cooling device at a covering temperature.

### III.LITERATURE REVIEW




Figure 6-21.—Water-cooled condenser.

Fig.4; water cooled Condensor

#### A. Plan and Heat Transfer Analysis of AC Condenser for Different Materials

An upgrade methodology is presented that is crucial in examining a finned tube condenser in the best arrangement and heating is being thought about and strengthened by convection in air-cooled condensers. A smoke pressure condenser for the cooling structure is examined on an air-cooling fins-pipe condenser. The condenser is checked for the substance and the coolant on the warmth transfer. For the tubing Copper alloy, aluminum 1100 and 1050, and 1100 edges for cutting were considered. The components were used. R12, R22, and R 134 are the coolants being transferred. In Pro/Engineer, 3D showing is performed and evaluation is carried out in Ansys.

#### B. Cooling condenser consolidated with a sprinkler system utilizing condensate water

Most of the cooling gear reduces the springiness of the air regulated by the building. The sensitively cold evaporator circle (under the dew point) enters water fury from the regulated weather, as a spoiling drink gains water from a bottle. The water is transported to discard the anger of water from the chilled room and its relative tenacity is thus removed. Since people are sucking to have ordinary refreshment through sweat spread from the skin, (fairly) drier air coolers

### IV.METHODOLOGY

During its whole lifespan, the life cycle approaches analyse the effect of a good or service. Decision makers frequently reflect on the impacts of utilising the good or service on one part of the life cycle, but a "cradle to graves" strategy is essential to fully grasp the importance. (1) the quantity and detection of energy and material and waste discharged into the atmosphere; (2) the assessment of the influence of the energies and materials used and discharged into the environment, and (2) the assessment of energy and materials used and released into the environment; (ISO, 1997). In the beginning, the ISO approach to LCA is to determine the research target and evaluate what elements are included and omitted. Inputs and outputs are then quantified and summarised during each step of the life cycle. The inventory findings are used in the effect evaluation to determine the environmental gain or harm. The findings should be translated and used after they have been completed. LCA is not inherently a straightforward operation. Each phase also helps form the preceding and future measures and optimise them. The ISO structure is summarised to execute an LCA






Fig.5; Life cycle Assessment Framework

## V. INTRODUCTION CAD

The high degree of incapacity and capacity of PCs shows that even fragrance bays and chemical instruments are arranged by modelers of the 1960s utilizing incredible techniques.

### A. CREO in Parametric Modules

- 1) Sketcher
- 2) Part modelling
- 3) Assembly
- 4) Drafting





Fig.6;3D in Model

### B. ANSYS IN Mechanical


ANSYS Mechanical for critical evaluation, including straight, nonlinear, and complex evaluations, is a small component examination tool. This thing for PC propagation gives limited segments to demonstrate lead ANSYS consolidates warm measurement and current scientific limitations of mechanical engineering, including acoustics, piezoelectric, warm fundamental, and thermoelectric testing.

## VI. THERMAL ANALYSIS OF CONDENSER

### A. Aluminum Alloy




Aluminum alloy Imported in Model




Meshed in Model

### B. Boundary In Conditions




Temperature




Heat in Flux

### C. Material -Copper




Temperature




Heat Flux

### D. Material -Aluminum




Temperature




Heat Flux

### E. Material -Copper




Temperature




Heat flux



# F. Material -Aluminum



Temperature



Heat Flux


Table I; Material -Copper

Mass Flow Rate	(kg/s)
inlet	1.9999995
interior-___msbr	2209.5713
outlet	-1.9981513
wall-___msbr	0
Net	0.0018482208


Table II; Heat In Transfer Rate

Total Heat Transfer Rate	(w)
inlet	-36353.133
outlet	-11344.112
wall-___msbr	46663.844
Net	-1033.4014

LENGTH-405mm




Pressure



Temperature





Heat Transfer Rate


Table III; Mass Flow Rate

Mass Flow Rate		(kg/s)
inlet		1.9999999
interior-_____msbr		2544.5417
outlet		-2.0020876
wall-_____msbr		0
Net		-0.0020877123


Table IV; Heat Transfer Rate

Total Heat Transfer Rate		(w)
inlet		-36353.172
outlet		-11745.404
wall-_____msbr		47533.996
Net		-564.58008

LENGTH-455mm



Pressure



Heat Transfer Coefficient


Table V; Mass Flow Rate

Mass Flow Rate	(kg/s)
inlet	1.9999998
interior-____msbr	2815.469
outlet	-2.0120621
wall-____msbr	0
Net	-0.012062311


Table VI; Heat Transfer Rate

Total Heat Transfer Rate	(w)
inlet	-36353.23
outlet	-12102.532
wall-____msbr	47752.813
Net	-702.9502

At Condenser Length-505mm



Pressure



Heat Transfer Coefficient

## VII. RESULT OF TABLES

Thermal in analysis

Material	Condenser length(mm)	Temperature (k)	Heat flux (w/mm <sup>2</sup> )
Aluminum alloy	345	28.026	0.068375
	405	28.023	0.073415
	465	28.024	0.069784
	505	28.025	0.069883
Copper	345	28.012	0.092377
	405	28.01	0.098348
	465	28.011	0.093316
	505	28.015	0.093398

## VIII. CONCLUSION

### A. Thermal in Analysis

CFD and thermal analyses are used to evaluate this heat transfer through convection in cooling by varying the condenser volume. The test is made of a vapor compression cycle air-cooled tube condenser for the cooling device. The tubing Copper and Aluminum alloys are the components considered. The coolants vary with R 12. CFD study, coefficient of heat transfer more at 505mm condenser range. The heat flux for copper materials with a condenser duration of 405 mm is more significant in thermal analysis. This is the strongest stuff we will finish Copper.

## IX. FUTURE SCOPE

The responsibility for cooling the house for a single family over the period 1985–2025 was included in this report. These pressures were in the shape of oil use, production of greenhouse gases and expense for the user. In the various areas of the 48 contiguous countries houses have been considered. Air conditioners are available on the market in different models and sizes. This research would take into account electrically driven, divided CACs that use steam-compressed cooling as it is the most popular method used in residential single-family cooling. Usually, these units vary from 1,5 tonnes to 5 tonnes, with 12,000 BTU of cooling for each tonne. This analysis takes into account the most popular scale, 3 tonnes. Methods such as evaporative coolers and single packaging units not fitting for this profile shall be omitted. Many other elements, such as the heat transfer and penetration by the building envelope, vent leakage and occupant behaviour, will substantially influence the efficiency of a building's air conditioning system. In order to render the research review possible, variables such as this which do not contribute directly to the CAC were omitted, but these factors and their potential effect on the results

## REFERENCES

- [1] Preordain consisting of pre-cooling going from basin quality as far as condensers about lessen units past may perhaps waly, walid chakroun along with nawaf k. Al-mutawa, cosmopolitan almanac going from dynamism scrutinize, figure 29, effect 8, scenario 781–794, quarter june 2005.
- [2] Air-Conditioning facts from the 1997 residential Energy Consumption Survey. [http://www.eia.doe.gov/emeu/consumptionbriefs/recs/aircound\\_use.htm](http://www.eia.doe.gov/emeu/consumptionbriefs/recs/aircound_use.htm)
- [3] Hayeter, Richard B., Phd.D. P.E. The Future of HVAC: The Perspective of One American. Presented at the 40<sup>th</sup> anniversary of the Netherlands Technical Association for Building Services. (TVVL), June 11, 1999, Amsterdam, The Netherlands. <http://www.eng.ksu.edu/people/rhayter/tvvlprapr.htm>
- [4] Home Energy Saver Web page. <http://homeenergysaver.lbl.gov>
- [5] Propst James L." Air Conditioner Condenser Optimization ".Georgia Institute of Technology
- [6] Design, Analysis, and Improvement of Energy System.





10.22214/IJRASET



45.98



IMPACT FACTOR:  
7.129



IMPACT FACTOR:  
7.429



# INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089  (24\*7 Support on Whatsapp)