



IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Volume: 9 Issue: IX Month of publication: September 2021 DOI: https://doi.org/10.22214/ijraset.2021.38108

www.ijraset.com

Call: 🕥 08813907089 🔰 E-mail ID: ijraset@gmail.com

Comparative Analysis & Design of Elevated Storage Reservoir (ESR) By Manually & Software

Asst. Prof A.V. Karvekar¹, Priyanka Pandit², Shital Autade³, Padmaja Kumbhar⁴, Sonal Kamble⁵ Vishwajit Patil⁶, Vinod Tamhanekar⁷

¹Assistant Professor, Dept. Of Civil Engineering, Ashokrao Mane Group of Institutions ^{2, 3, 4, 5, 6, 7}Btech Students, Dept. Of Civil Engineering Ashokrao Mane Group of Institutions

Abstract: Water tanks are important public utility and industrial structure. The design and construction method used in reinforced concrete are influenced by the prevailing construction practices, the physical property of the material and the climatic conditions water tanks are classified on the basis of their shape and position of structure storage reservoirs and overhead tank are used to store water all tanks are designed as crack free structure to eliminate any leakage. The principle objective of this project is to plan, analysis and design a circular overhead tank of 750lakh litters capacity. In this project all structural elements of circular water tank are analysed and design by using manually and ETAB software . this project giuesin brief ,The theory behind the design of liquid retaining structures (Elevated circular water tank) using limit state method with reference to IS: 3370 (2009)and IS456:2000 The behaviour of structure for the parameters like story drift ,displacement stiffness ,deflection ,storey shear ,base shear , area of steel ,for circular water tank are studied on ETAB software and then comparison of the results is made between manually design By this study we say that the circular water tank analysis and design on ETAB software is more economical and safe than manually design of water tank.

Keywords: Circular water tank, Seismic pressure, Population Forcasting, Limit state method, working stress method, ETAB.

I. INTRODUCTION

Without water survival is impossible. Water is one of the most important substances on earth. All plants and animals must have water to survive. As water is very precious and due to the scarcity of drinking water in day to day life one has to take care of every drop. A water tank is used to store water for daily requirements like drinking ,washing etc.

An elevated water tank is a large water storage container constructed for the purpose of holding water supply at certain height to provide sufficient pressure in the water distribution system. These tanks have various types of supports structures like RC Braced Frame, Steel Frame, RC Shafts and even masonry pedestal. The most commonly used staging in practice is the frame type. The main components of this type of staging are columns and braces.

The staging acts like a bridge between the overhead container and foundation to transfer loads acting on the tank. Thus water tanks are very important for public utility and for industrial structure and also to withstand more design forces. The frame spport of the ELSR should have adequate strength to resists axial loads moment and shear force due to lateral loads. These forces depends upon total weight of structure, which varies with the amount of water present in the container

- A. Objective
- 1) To collect the data and planning of ESR.
- 2) To analyse ESR design by manually.
- *3)* To design the ESR by using software.
- 4) To compare the result obtained from manual design and software design.
- B. Scope of the Project
- 1) We design a circular tank for a particular capacity and performed its manually analysis and design on software
- 2) It helps to find the overall demand and per capita demand for a particular area
- 3) To know about the design philosophy for the safe and economical design of water
- 4) To increase the design life period and serviceability of the structure



ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 7.429 Volume 9 Issue IX Sep 2021- Available at www.ijraset.com

II. METHODOLOGY



III. DATA COLLECTION

Table 1:	Details	of data	collection
----------	---------	---------	------------

1	Capacity of tank	7,50,000
2	Height of tankl from ground	19 m
3	Grade of concrete	M 25
4	Free board	0.2 m
5	Width of gallery	1 m
6	Water stored from	Warna river
7	Thickness of wall	320 mm
8	Use of water	For domestic use
9	Tank provided in area	A/P,Kini,Tal-Hatkanangle,Dist-Kolhapur
10	Current population in year 2011	7786
11	Population forecasting 2021	10782.66
12	Distribution system	By symphon



International Journal for Research in Applied Science & Engineering Technology (IJRASET) ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 7.429 Volume 9 Issue IX Sep 2021- Available at www.ijraset.com

Permissible stresses for M25 and Fe415

Population Forecasting

Year	Population	Increase per decades	$B_{cbc} = 8.5 \text{ N/mm}^2$
1971	2991	-	$E_{st} = 130 \text{ N/mm}^2$
1981	4020	1029	$E_{cc} = 6N/mm^2$
1991	5235	1215	Arithmetical progress method
2011	7786	2251	Pn = Po+nx
	Average	1498.33	P2031=7786+2x1498.33 P2031=10782.66

IV. MANUAL DESIGN OF CIRCULAR WATER TANK

The water tank is designed for the kini village population of 7786.based on the per capita demand for village the capacity of the watger tank is reached as 7,50,000.the salient features of the overhead water tank is tabulated below.

Component	Description	Ast provided
name		
Water tank wall	At base -	3351mm2
	Total steel (Ast provided)	
	Vertical steel-	
	-In lower portion of vertical direction	2053mm2(16mmΦ@100mm c/c)
	- Curtail alternate bars on outer face	
		768mm2(10mmΦ@250mm c/c)
Circular base	-Steel at design moment	-4809.63mm2(10#25mmΦ@ 250mm c/c)
slab		
	-Steel at radial moment	-2325mm2(12#16mmΦ@ 150mm c/c)
	-Steel at circumferential	-2431mm2(8#20mmΦ@ 120mm c/c)
	-Steel at remaining surface	-960mm2(12mmΦ@ 150mm c/c)
Bottom ring	- Reinforcement at support	-3949mm2(8#25mmΦ@ 140mm c/c)
beam		
	-Reinforcement at mid span	-1718mm2(4#25mmΦ@ 200mm c/c)
	Stirrups	-12mmΦ-2legged vertical stirrups @ 70mmc/c near
		support and 120mm in middle half portion
	- Side face Reinforcement	-375mm2(2#16mmΦ@300mm c/c)
Column	- Main steel (Longitudinal bars)	-8#32mmΦ
	- Lateral ties	-10mmΦ@300mmc/c
Draging	Ast pro	2520mm2(8#25mm@at.ton.and.hottom)
Dracing	- Ast pro	-5559mm2(6#25mmΨat top and bottom)
	- Surrups	- roming 2 legged surrups @520mme/c

Table 2: Steel design in component by manual



International Journal for Research in Applied Science & Engineering Technology (IJRASET) ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 7.429

Volume 9 Issue IX Sep 2021- Available at www.ijraset.com

Design details of circular water tank (Diagram)



V. DESIGN OF CIRCULAR TYPE TANK ON SOFTWARE

- A. Design Details on Software
- 1) Step 1 Defining material and section property. The material properties and section properties should be defined for the water tank modelling.
- 2) Step 2 Assigning the material and section properties . After the material and section properties , the properties are assigned for the structure in the software .
- 3) Step 3 Assigning pt supports . The fixed supports are assigned to the structure at the base to the columns after defining material and section property.
- 4) Step 4 Defining load patterns .The various loads acting on structure are dead load , live load , wind load ,earthquake load (seismic load) and water pressure these loads are defined .
- 5) Step 5 Assigning the loads . in ETABs Software the dead load of the structure is taken directly . we need not to apply dead load again .Then other remaining loads should be assigning for the structure as per IS codes.
- *a*) Live load = $2KN/m^2$ per IS -875(part 2)
- b) Seismic loads as per IS 1893 (PART_3)
 - -Zone 3(pune) - Z = 0.10 - I = 1.5 - R =5 - Ta = 0.09h/^vd
- c) Wind load as per IS -875 PART 3
 - Location = pune(Vb)m/ssec = 33m/sec
 - -(k1) = 1
 - -(k2) = 1
 - -(k3) = 1.046
 - (V2) = Vb *K1 * K2* k3
 - $(Pz) = 0.6*Vz^2$



International Journal for Research in Applied Science & Engineering Technology (IJRASET)

ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 7.429 Volume 9 Issue IX Sep 2021- Available at www.ijraset.com

- 6) Step 6- Load combinations .In ETABs the load combinations will be automatically generated and can also be defined by user . there are 26 load combinations that are defined according to IS 875 (part 5) : 1987 based on serviceability conditions. After the completions of above steps the analysis iscarried and then results will be obtained .
- 7) *Step* 7 After completion of analysis the results are obtaining the software by that values the design is done manually by working stress and limit state method.



Photo 1. Loads Assinging the loads

Photo 2. 3d Model of Tan

VI. SOFTWARE DESIGN OF CIRCULAR TANK

Component	Description	Ast provided
name		
Water tank	At base -	3056 mm2
wall	Total steel (Ast provided)	
	Vertical steel-	
	-In lower portion of vertical	12 mm φ@275 mm c/c
	direction	
	- Curtail alternate bars on outer	12mm φ@275mm c/c
	face	
Circular base	Steel at design moment	4535 mm2(12#20mmΦ@ 200 mm c/c)
slab	Steel at radial moment	2049 mm2(6#20mmΦ@ 100 mm c/c)
	Steel at circumferential	2241 mm2(10#16mmΦ@ 100 mm c/c)
	Steel at remaining surface	745 mm2(10 mmΦ@ 100mm c/c)
Bottom ring	Reinforcement at support	3539 mm2(8#16mmΦ@ 100 mm c/c)
beam	Reinforcement at mid span	1508 mm2(6#16mmΦ@ 150mm c/c)
	Stirrups	12mmΦ-2legged vertical stirrups @ 70mmc/c near
	Side face Reinforcement	support and 120mm in middle half portion
		300mm2(12mmΦ @275mm c/c)
Column	- Main steel (Longitudinal bars)	18#12mmΦ
	- Lateral ties	10mmΦ@100mmc/c
Bracing	Ast pro	3149 mm2(12#20mm@at ton and bottom)
Dracing	Stimus	$10 \text{ mm} \Phi @250 \text{ mm} c/c$
	- Sunups	1011111Φ (ω 23011111C/C

Table 3:Steel design in components by software



International Journal for Research in Applied Science & Engineering Technology (IJRASET) ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 7.429 Volume 9 Issue IX Sep 2021- Available at www.ijraset.com

VII. RESULT

SR NO	Component part of water tank	Quantity of steel	Quantity of steel
		(manual)(kg)	(software)(kg)
1	wall	506.75	174.22
2	Base slab	984.07	798.91
3	Bottom ring beam	703.61	298.15
4	column	826.83	642.65
5	bracings	4544.06	4008.29
		Total=19775.57kg	Total =15325kg
		=19775.57/1000	=15325/1000
		=19.77tones	=15.32tone

Table 4: Quantity of steel design by manually and by software

VIII. CONCLUSION

Storage of water in the form of tanks for drinking and washing purpose swimming pools for exercise and enjoyment and sewage sedimentation tanks are gaining increasing importance in the present day life. For small capacities we go for rectangular water tanks while foe bigger capacities we provide circular water tanks.

Design of circular water tank is a very tedious method the whole structure is designed manually considering M20 grade concrete and fe415 steel. After manual design and analysis in ETAB our structure is safe for both structural design and sesmic analysis with respect to load applied

Software analysis and design is always beneficial over the conventional method of analysis and design of water tank . Manual analysis and design requires lengthy complicated procedure while software requires less time and easy design and analysis. In manually design of water tank the Total quantity of steel required 19 tone of whole structure. And other hand by using ETAB software the Total quantity of steel required 15 tone. Hence we finally conclude that using etab software there is saving 4.5 tone quantity of total steel in the whole structure design

REFERENCES

Reference Paper's

- Mohammad Quais Khan, (M.Tech scholar, civil engineering department, SSSUTMS, M.P., INDIA), etal was plublished research paper on the topic of "Analysis & design of Intze water tank as per IS:3370 & IS:456-2000 using STAAD PRO software", Vol-5, Issue-5, Year-2019.
- [2] Mareddy Arun Kumar (Department of civil engineering N.B.K.R, institute of science & technology, Nellore, India), etal was published research paper on the topic on "Analysis & design of a overhead circular water tank in N.B.K.R.I.S.T using STAAD PRO software, Vol-5, Issue- 5, Year- May 2018.
- [3] Mainak Ghoshal, Jr. secretary, coal ash institute of india international transcation of engineering & science ,was published research paper on the topic of "water tank design using STAAD PRO software", Vol-1, issue-2, year- January 2019.
- [4] Dunnala Lakshmi Anuja, etal was published journal paper on the topic of "Planning, analysis & design of residential building (g+5) by using STAAD PRO", Journal paper-ISSN:2321-9939, Vol-7, Issue-3, year-2019.
- [5] R. sanjaynath (Assistant Professor, Department Of Civil Engineering, Saveetha University, Chennai-602105, Tamil Nadu, India), etal was published journal paper on the topic of "Planning, analysis & design of (G+20) multi storey residential building using STAAD PRO", 139-145, Vol-119, N0-17, year-2018.
- [6] Mohammad Quais Khan, etal was published paper on 'Analysis & design of intze water tank as per IS 3370 & IS 456-2, Vol-5, issue-6, Year-2019.

Is Code And Reference Book

- [1] Indian standard "concrete structure for storage of liquids" IS:3370:2009 [part -2] reinforced concrete structures.
- [2] Indian standard "plain and reinforced concrete" IS:456:2000 code of practice.
- [3] Advanced R.C.C design [R.C.C VOLUME 3] by S.S BHAVIKATTI.











45.98



IMPACT FACTOR: 7.129







INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089 🕓 (24*7 Support on Whatsapp)